



P.O. Box 519

1351 W. Second Street

379 Davis Road, Unit #3

Corona, California 92878-0519

Oconomowoc, Wisconsin 53066

Oakville, Ontario, Canada L6J 2X2

Phone: 909-735-8220; 800-543-3885; 800-735-1922

Phone: 262-567-2288

Phone: 905-844-1791; 800-361-9473

Fax: 909-735-2372; 800-752-6001; 800-735-0857

Fax: 262-567-0857


Fax: 905-844-2533; 800-663-0933

# INSTALLATION INSTRUCTIONS • DUCT-O-BAR FIGURE 8 SYSTEMS

## SUPPLEMENTARY INSTALLATION INSTRUCTIONS

### FE-1DC JOINT KEEPER CLIP

1. After conductor bar sections have been pulled together, install the joint keeper clip by inserting the small end (A) into a connector tool hole from the seam side of the bar.
2. To snap the other end of the joint keeper (B) into the other connector tool hole, line up the clip near the hole, then apply pressure to the clip in the area shown by the arrow. Use a pliers, if necessary, to help force the clip into the hole.
3. Install the splice cover over the exposed sections of the conductor bar in the normal manner.



Joint Keepers are designed to prevent the conductors from pulling apart at the joints, especially the softer metals such as copper.

### CAUTION

MAKE CERTAIN POWER SUPPLY IS DISCONNECTED BEFORE INSTALLING, REPAIRING, OR WORKING IN THE PROXIMITY OF ANY ELECTRICAL SYSTEM. ONLY QUALIFIED ELECTRICAL PERSONNEL SHOULD INSTALL OR REPAIR THESE PRODUCTS.