

7030 Ryburn Dr. Millington, TN Phone: (901) 873-5300 Fax: (901) 873-5301 www.gohispeed.com

September 26, 2019

Nucor Roll Mill Jackson-Flowood, MS

Subject: September vibration survey

Most of the machines surveyed were found to be in good condition with the exception of the following:

QualiTest® uses a four step rating system for defects.

<u>Class I:</u> Defect is present, but effect on reliability is not clear; no immediate action is required. Continue to normally monitor.

<u>Class II:</u> Defect (s) present that may cause problem in long term (2-6 months). Repair during normal maintenance scheduling. Continue to monitor.

<u>Class III:</u> Defect (s) present that may cause failure in short term (less than 2 months). This should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.

<u>Class IV</u>; Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs

Hi-Speed Industrial Service tests and inspects industrial machinery and equipment and makes recommendations concerning maintenance and repairs based on its experience in the field of industrial repair and maintenance. The information contained herein is provided as an opinion only, not as a guaranty or warranty of the matters discussed herein.

Defects

Roll Stand 1A Planetary Gearbox

Overall vibration varies with each survey and may be influenced somewhat by speed and load. The vibrations in the planetary section still show signs of distress. We will continue to monitor this unit closely. Still rated as a **CLASS I** defect for now.

Roll Stand 2 MOTOR

Data of the motor indicates some signs of bearing issue possible in the motor. We will monitor this closely. Rated as a **CLASS I** defect for now.

Roll Stand 2 Cooling Fan Motor

Motor data suggests mechanical looseness of the motor fits and or fan hub. A rub can also cause this type of vibration. Vibration levels are not high levels as of now, but this issue will be monitored closely. Rated as a **CLASS II** defect.

Roll Stand 4

Gearbox is starting to show some signs of gear wear and or gear misalignment at the input to intermediate side. Speed and load may have some effect on the fluctuation of amplitude; however, signs of wear do exist. We will continue to monitor this issue closely. Rated as a **CLASS I** defect for now.

Roll Stand 5

Vibration has decreased slightly in the gearbox outboard side this survey. A dominant gear mesh vibration is present towards the output of the gearbox. The up and down amplitude of this peak from month to month is likely due to change in tooth load and machine speed. We will continue to monitor this very closely. Rated as a **CLASS I** defect for now.

Roll Stand 5 Cooling Fan Motor

There appears to be a vibration in this unit that may be due to imbalance of the fan wheel. There may also be a slight electrical issue in the motor as well, but the dominant vibration is due to the possible imbalance. We will monitor this closely. Rated as a **CLASS II** defect.

Roll Stand 6

A dominant gear mesh vibration is present towards the output of the gearbox. Overall vibration was about the same as last month. The up and down amplitude of this peak is likely due to change in tooth load and speed. This issue seems to have begun after gearbox was repaired. We will continue to monitor this very closely. Rated as a **CLASS I** defect.

Roll Stand 7

Output side of the gearbox casing was extremely high this survey. At the output side of the gear box casing the vibration was saturating the accelerometer. We suspect this to be possibly due to a resonant gear mesh frequency vibration. The up and down amplitude of this peak from month to month is likely due to change in tooth load and machine speed. We will continue to monitor this very closely. Because vibration was so high this month, this is now rated as a **CLASS III** defect.

Roll Stand 13 Cooling Fan Motor

Cooling fan motor data is showing vibrations associated with rotor issues such as loose or broken rotor bars. This is causing a higher than normal 1 x rpm vibration. We will monitor this closely. Rated as a **CLASS I** defect for now.

West Reheat hydraulic pump

Equipment was not in service this survey; however, the following most likely still applies: The pump has a much higher vibration this survey. Increase from .3 to .6 ips-pk. Spectrum shows high vibration at 2 x pump vane pass frequency with rpm sidebands. This could be due to clogged filter if equipped or other issue such as pump wear. Inspect pump soon. Rated as a **CLASS III** defect.

Ejector Fan

The motor appears to be thrusting slightly again this month. Overall vibration levels are within acceptable limits this survey. This issue will continue to be monitored closely. Rated as a **CLASS I** defect.

Furnace CT Drive North

Large increase in 1 x rpm vibration in the motor outboard. This may be due to coupling issue, shaft run-out, loose base. Inspect the unit for these issues soon. Rated as a **CLASS II** defect.

Scale Pit NORTH Pump

There is a high 1 x rpm vibration in the top end of the motor that may be due to an issue with the pump. For now, ensure that the pump is operating at the proper flow parameters. Pump may also have some imbalance or other mechanical problem which could cause this type of vibration. For now, this is a **CLASS II** defect.

South Quincy Air Compressor

Motor vibration has increased slightly this survey. Data has shown (in the past) high frequency electrical type vibration such as 2 x line frequency, stator slot pass, and or rotor bar pass frequency vibrations. This usually indicates an electrical issue is present such as winding issue, rotor issue, etc. We will monitor this issue closely. Rated as a **CLASS I** defect.

As always, it has been a pleasure to NUCOR Steel Flowood, MS. If there are any comments or questions, do not hesitate to contact us.

Sincerely,

ISO Certified Vibration Analyst, Category III

Kevin W. Morriell

INDUSTRIAL SERVICE

QualiTest ® Diagnostics

Cell: 901-486-4565

Email: kwilliam@gohispeed.com

Database: nucorja9.rbm Station: Roll Mill Rolls

MEASUREMENT POINT		OVERALL LEVEL	HFD / VHFD				
STD1A	- Stand 1	A	(19-Sep-19)				
-							
	мон	OVERALL LEVEL .049 In/Sec	.020 G-s				
	MIH	.041 In/Sec					
	MIA		.052 G-s				
	СОН	.072 In/Sec .188 In/Sec	.084 G-s				
	GIA		.055 G-s				
	GIH	.133 In/Sec	.389 G-s				
	GI2	.103 In/Sec	.256 G-s				
	GI3	.089 In/Sec					
	GI4	.085 In/Sec	.747 G-s				
	GI5	.065 In/Sec	.019 G-s				
		.046 In/Sec	.019 G-S				
	GI6	.046 In/Sec	.057 G-s				
	GOH	.036 In/Sec	.026 G-s				
STD2A	- Stand 2	A	(19-Sep-19)				
		OVERALL LEVEL	1K-20KHz				
	MOH	.051 In/Sec	.047 G-s				
	MIH	.049 In/Sec	.015 G-s				
	MIA	.083 In/Sec	.029 G-s				
	COH	.189 In/Sec	.035 G-s				
omp 1	Q+1 1		(10.0 10)				
STDI	- Stand 1		(19-Sep-19)				
		OVERALL LEVEL	IK-2UKHZ				
	MOH	.053 In/Sec .117 In/Sec	.066 G-s				
	MIH						
	MIA	.106 In/Sec	.151 G-s				
	GIA	.051 In/Sec	.037 G-s				
	GIH	.058 In/Sec	.061 G-s				
	СОН	.115 In/Sec	.057 G-s				
STD2	- Stand 2		(19-Sep-19)				
-		OVERALL LEVEL					
	MOH	_					
	MIH	.112 In/Sec .066 In/Sec .190 In/Sec	102 G-s				
	MIA	.190 In/Sec	.102 G-s .234 G-s				
	GIA	068 Tn/Sec	.073 G-s				
	GIH	.049 In/Sec	.419 G-s				
	COH	.383 In/Sec	.470 G-s				
	COII	.303 111, 566	.470 0 5				
STD3	- Stand 3		(19-Sep-19)				
		OVERALL LEVEL	1K-20KHz				
	MOH	.059 In/Sec	.294 G-s				
	MIH	.083 In/Sec					
	MIA	.117 In/Sec	.083 G-s				
	GIA	.024 In/Sec	.0046 G-s				
	GIH	.037 In/Sec	.045 G-s				
	COH	.277 In/Sec					
STD4	- Stand 4		(19-Sep-19)				
		OVERALL LEVEL					
	MOH	.073 In/Sec					
	MIH	.074 In/Sec					
	MIA	.227 In/Sec					
	GIA	.120 In/Sec					
	GIH	.073 In/Sec					
	СОН	.247 In/Sec	.074 G-s				
STD5	- Stand 5		(19-Sep-19)				
כענט	- Scand 3	OVERALL LEVEL	_				
		OAEVWIT TEAFT	TIV-ZOIVUS				

	MOH			In/Sec	.066 G-s	
	MIH			In/Sec	.124 G-s	
	MIA			In/Sec		
	GIA			In/Sec		
	GIH		.046	In/Sec	.058 G-s	
	GOH			In/Sec	.127 G-s	
	СОН		.383	In/Sec	.037 G-s	
CIED C	Q+			/1.0) G 10)	
STD6	- Stand		OTTEDA		-Sep-19)	
	мон		OVERA	LL LEVEL	.100 G-s	
	MIH		.0/1	In/Sec In/Sec	.100 G-s	
	MIA			In/Sec In/Sec		
	GIA					
	GIH		.030	In/Sec	.033 G-s .026 G-s	
	GOH			In/Sec		
	COH			In/Sec		
	COH		.209	In/Sec	.045 G-S	
STD7	- Stand	1 7		(19	-Sep-19)	
	5 55	-	OVERA	LL LEVEL		
	MOH		.117	In/Sec	.102 G-s	
	MIH		111	In/Sec	.290 G-s	
	MIA			In/Sec		
	GIA		.102	In/Sec	.030 G-s	
	GIH		197	In/Sec	.043 G-s	
	GOH				11.94 G-s	
	COH			In/Sec		
	0011		.551	211, 500	.110 0 0	
STD8	- Stand	l 8		(19	-Sep-19)	
			OVERA	LL LEVEL	1K-20KHz	
	MOH		.063	In/Sec	.061 G-s	
	MIH		.065	In/Sec	.069 G-s	
	MIA		.055	In/Sec	.139 G-s	
	GIA		.049	In/Sec	.032 G-s	
	GIH		.059	In/Sec	.295 G-s	
	СОН			In/Sec	.032 G-s	
STD9	- Stand	1 9		(19	-Sep-19)	
				LL LEVEL		
	MOH		.061	In/Sec	.069 G-s	
	MIH			In/Sec	.110 G-s	
	MIA			In/Sec	.028 G-s	
	GIA		.087	In/Sec	.059 G-s	
	GIH				.384 G-s	
	СОН		.255	In/Sec	.066 G-s	
amp 1.1	0		440 - 401			
STD11	- Stand	. 11	OVEDA	LL LEVEL (19)-Sep-19) 1K-20KHz	
	мон		00ERA	In/Sec	.021 G-s	
	MIH					
	MIA		0.00	In/Sec In/Sec In/Sec	.053 G-s	
	GIA		077	In/Sec	.086 G-s	
	GIH				.119 G-s	
	GOH			In/Sec	.308 G-s	
	COH		124	In/Sec	.078 G-s	
				,		
STD12	- Stand	l 12	(19-Sep-19)			
				LL LEVEL	-	
	MOH		.027	In/Sec	.022 G-s	
	MIH		025	In/Sec	.071 G-s	
	MIA		.031	In/Sec	.041 G-s	
	СОН		.109	In/Sec	.060 G-s	
STD13	- Stand	l 13			-Sep-19)	
				LL LEVEL		
	MOH			In/Sec		
	MIH		.113	In/Sec		
	MIA			In/Sec	.146 G-s	
	GIA			In/Sec	.044 G-s	
	GIH		.039	In/Sec	.023 G-s	

GOH COH			Sec Sec					
STD14 - Stand 14 (19-Sep-19								
51014	- Stand 14	OVERALL L		ep-19)				
MOH	!	.095 In/	Sec.	.121 G-s				
MIH		.095 In/: .072 In/:	Sec	.046 G-s				
MIA		.054 In/	Sec	.143 G-s				
GIA	L		Sec	.355 G-s				
GIH	I	.080 In/s	Sec	.140 G-s				
GOH	<u>I</u>	.070 In/		.230 G-s				
COH	I	.349 In/	Sec	.177 G-s				
NORTH AC - NORTH AIR COMPRESSOR QUINCY (19-Sep-19) OVERALL LEVEL 1 - 20 1								
MOH	•	167 Tm/	EVEL .	.156 G-s				
MIH		.167 In/: .161 In/:	Sec	.150 G-s				
MIA		.212 In/	Sec	.169 G-s				
MIA	•	OVERALL L		1K-20KHz				
CIA		.244 In/	Sec	.579 G-s				
CIH		.213 In/	Sec	.524 G-s				
COH			Sec					
SOUTH AC - SOUTH AIR COMPRESSOR QUINCY (19-Sep-19)								
		OVERALL L	EVET.	1 - 20 KHz				
MOH	Ī	.294 In/: .319 In/:	Sec	.245 G-s				
MIH	I	.319 In/	Sec	.108 G-s				
MIA	L	.250 In/	Sec	.110 G-s				
		OVERALL LI .443 In/	EVEL :	lK-20KHz				
CIA		.443 In/	Sec					
CIH		.529 In/		.480 G-s				
COH	<u>[</u>	.361 In/	Sec	.367 G-s				
WEST AC	- WEST AIR COMPR							
		OVERALL LI		1 - 20 KHz				
MOH		.138 In/: .149 In/:	Sec	.103 G-s				
MIH MIA		.149 In/s	sec	.134 G-s				
MIA	_							
CIA		OVERALL LI .203 In/	even . Sec	.698 G-s				
CIE		229 Tn/	Sec	649 G-s				
COH			Sec					
р	atabase: nucorja	9.rbm						
S	Station: Roll Mi	II Utilities						
MEASUREMEN	T POINT	OVERALL LE		HFD / VHFD				
HYDPMP1	- Hydraulic Pump							
		OVERALL LI	EVEL :	LK-20KHz				
MOH		.175 In/	Sec Sec	.247 G-s				
MIH								
PIV	•	.245 In/	Sec	.819 G-S				
HYDPMP2	- Hydraulic Pump							
мон	i	OVERALL LI .177 In/: .393 In/:						
MIH		.393 In/	Sec	.318 G-s .232 G-s				
PIV		244 Tn/	sec Sec :	.232 G-8 1 710 G-8				
FIV		.277 III/i		u G-s				
DESFAN	- Desolution Fan		(19-9	ep-19)				
		OVERALL L						
MOH	I		Sec					
MIH		.033 In/	Sec	.045 G-s				
COMFAN	- Combustion Air							
		OVERALL L	EVEL :	lK-20KHz				
MOH	Ī	.140 In/	Sec	.525 G-s				

```
.424 G-s
      MIH
                            .112 In/Sec
                            .186 In/Sec
      MIA
                                            .354 G-s
                            .088 In/Sec
                                            .165 G-s
      FIH
                            .129 In/Sec
                                            .842 G-s
      FOH
EJCFAN - Ejector Air Fan
                                     (19-Sep-19)
                           OVERALL LEVEL 1K-20KHz
      MOH
                            .068 In/Sec
                                           .374 G-s
      MIH
                            .062 In/Sec
                                           .592 G-s
                            .068 In/Sec
                                           .524 G-s
      MIA
                                           .302 G-s
      FIH
                            .043 In/Sec
      FOH
                            .102 In/Sec
                                            .531 G-s
COLPMP2 - Furnace Cooling Pump center (19-Sep-19)
                           OVERALL LEVEL 1K-20KHz
                                          .405 G-s
      MOH
                            .179 In/Sec
                                            .127 G-s
      MIH
                            .163 In/Sec
                            .094 In/Sec
      MIA
                                            .264 G-s
                                   (19-Sep-19)
FCTSOUTH - Furnace CT Drive South
                           OVERALL LEVEL 1K-20KHz
                                           .050 G-s
      MOH
                           .093 In/Sec
                                          .064 G-s
      MIH
                            .082 In/Sec
      MIA
                            .083 In/Sec
                                           .088 G-s
FCTNORTH - Furnace CT Drive North (19-Sep-19)
                           OVERALL LEVEL 1K-20KHz
                            .458 In/Sec
      MOH
                                          .079 G-s
                                         .149 G-s
.062 G-s
      MIH
                            .313 In/Sec
      MIA
                            .181 In/Sec
                               (19-Sep-19)
SCLPMP2 - Scale Pit Pump North
                           OVERALL LEVEL
                                          1K-20KHz
                                          .188 G-s
.317 G-s
      MOH
                           .356 In/Sec
                           .277 In/Sec
      MIH
                           .192 In/Sec
                                           .095 G-s
      MIA
      PIH
                           .185 In/Sec
                                           .083 G-s
CTWTR2 - CT Pump West
                                     (19-Sep-19)
                           OVERALL LEVEL 1K-20KHz
                           .106 In/Sec .250 G-s
.060 In/Sec .076 G-s
      MOH
      MIH
                            .107 In/Sec
                                            .088 G-s
      MIA
MILWTR2 - Mill Water Pump Center
                                   (19-Sep-19)
                           OVERALL LEVEL 1K-20KHz
      MOH
                           .099 In/Sec
                                           .395 G-s
                                            .737 G-s
      MIH
                            .045 In/Sec
      MIA
                           .066 In/Sec
                                           .472 G-s
```

Clarification Of Vibration Units:

Acc --> G-s RMS
Vel --> In/Sec PK