



QualiTest® Diagnostics

7030 Ryburn Dr. Millington, TN

Phone: (901) 873-5300

Fax: (901) 873-5301

www.gohispeed.com

June 19, 2020

Nucor Roll Mill
Jackson-Flowood, MS

Subject: June vibration survey

Most of the machines surveyed were found to be in good condition with the exception of the following:

QualiTest® uses a four step rating system for defects.

Class I: Defect is present, but effect on reliability is not clear; no immediate action is required.
Continue to normally monitor.

Class II: Defect (s) present that may cause problem in long term (2-6 months). Repair during normal maintenance scheduling. Continue to monitor.

Class III: Defect (s) present that may cause failure in short term (less than 2 months). This should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.

Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs

Hi-Speed Industrial Service tests and inspects industrial machinery and equipment and makes recommendations concerning maintenance and repairs based on its experience in the field of industrial repair and maintenance. The information contained herein is provided as an opinion only, not as a guaranty or warranty of the matters discussed herein.

Defects

Roll Stand 1A Planetary Gearbox

Overall vibration amplitudes are varying with survey while gearbox data show signs of distress. We will continue to monitor this unit closely. Still rated as a **CLASS I** defect for now.

Roll Stand 1 Motor

There is a significant amount of 360 Hz. vibration especially at the drive end axial of the motor. There are also several rpm sidebands around the 360 Hz. peak. This indicates a drive problem such as SCR card fault. There could also be an issue with the armature. It is recommended to inspect the drive as soon as practical. This issue will be monitored closely. Because of the electrical vibration, this is rated as a **CLASS II** defect.

Roll Stand 2 int. Gearbox

Input rpm sidebands around the gear mesh frequencies indicate possible oscillation of the input gear set. This could be from an issue with the speed synch on the drives, drive line slop, or some other process issue. Gearbox may need an internal inspection in the future. Rated as a **CLASS I** defect.

Roll Stand 4

Int. gearbox vibration has varied from month to month. Data has been showing some signs of gear wear and or gear misalignment at the input to intermediate side. Speed and load may have some effect on the fluctuation of amplitude. We will continue to monitor this issue closely. Rated as a **CLASS I** defect.

Roll Stand 5

Vibration decreased slightly in the gearbox outboard side this survey. A dominant gear mesh vibration is present towards the output of the gearbox. The up and down amplitude of this peak from month to month is likely due to change in tooth load and machine speed. We will continue to monitor this very closely. Rated as a **CLASS I** defect for now.

Roll Stand 5 Cooling Fan Motor

There still appears to be a vibration in this unit that may be due to imbalance of the fan wheel. Inspect, clean fan wheel as time allows. Ensure all bolts are tight. We will monitor this closely. Rated as a **CLASS II** defect.

Roll Stand 6

A dominant gear mesh vibration is present towards the output of the gearbox. Overall vibration decreased slightly from last month. The up and down amplitude of this peak is likely due to change in tooth load and speed. This issue seems to have begun after gearbox was repaired. We will continue to monitor this very closely. Rated as a **CLASS I** defect.

Roll Stand 7

Output side of the gearbox vibration increased this survey. We still suspect this to be possibly due to a resonant gear mesh frequency vibration. The up and down amplitude of this peak from month to month is likely due to change in tooth load and machine speed. We will continue to monitor this very closely. Rated as a **CLASS I** defect.

Roll Stand 13 Cooling Fan Motor

Fan appears to have vibration associated with fan imbalance. Resonance may also be a factor as this vibration does seem to vary slightly depending on the speed of the DC motor. We will monitor this closely. Rated as a **CLASS I** defect.

Ejector Fan

Motor axial vibration has increased to .45 ips-pk which is highest on record. Spectral data shows 2 and 3 x rpm vibrations at the inboard axial. This could be caused by a coupling issue, possible bent motor shaft, or rotor bar

issues. Fan bearings are also still showing some signs of possible looseness. Ensure bearing clearances are set properly. Couplings should also be checked. Check motor shaft with a dial indicator to confirm if shaft is bent. We will monitor this closely. Inspect as soon as time allows. Because of the high motor axial, this is rated as a **CLASS III** defect.

Abbreviated Last Measurement Summary

Database: nucorja9.rbm
 Station: Roll Mill Rolls
 Report Date: 19-Jun-20 13:51

MEASUREMENT POINT	OVERALL LEVEL	HFD / VHFD
-----	-----	-----
STD1A - Stand 1A	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.063 In/Sec	.012 G-s
MIH	.038 In/Sec	.014 G-s
MIA	.063 In/Sec	.122 G-s
COH	.285 In/Sec	.090 G-s
GIA	.022 In/Sec	.018 G-s
GIH	.043 In/Sec	.056 G-s
GI2	.033 In/Sec	.030 G-s
GI3	.029 In/Sec	.104 G-s
GI4	.025 In/Sec	.113 G-s
GI5	.014 In/Sec	.016 G-s
GI6	.012 In/Sec	.032 G-s
GOH	.015 In/Sec	.013 G-s
STD2A - Stand 2A	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.048 In/Sec	.0085 G-s
MIH	.069 In/Sec	.047 G-s
MIA	.109 In/Sec	.018 G-s
COH	.074 In/Sec	.083 G-s
STD1 - Stand 1	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.077 In/Sec	.030 G-s
MIH	.081 In/Sec	.021 G-s
MIA	.226 In/Sec	.069 G-s
GIA	.084 In/Sec	.0056 G-s
GIH	.037 In/Sec	.014 G-s
COH	.114 In/Sec	.035 G-s
STD2 - Stand 2	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.057 In/Sec	.039 G-s
MIH	.069 In/Sec	.045 G-s
MIA	.161 In/Sec	.127 G-s
GIA	.034 In/Sec	.014 G-s
GIH	.017 In/Sec	.022 G-s
COH	.115 In/Sec	.054 G-s
STD3 - Stand 3	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.055 In/Sec	.094 G-s
MIH	.116 In/Sec	.054 G-s
MIA	.311 In/Sec	.177 G-s
GIA	.036 In/Sec	.038 G-s
GIH	.030 In/Sec	.029 G-s
COH	.122 In/Sec	.034 G-s

STD4	- Stand 4	(18-Jun-20)
	OVERALL LEVEL	1K-20KHz
MOH	.035 In/Sec	.027 G-s
MIH	.056 In/Sec	.0078 G-s
MIA	.073 In/Sec	.059 G-s
GIA	.032 In/Sec	.011 G-s
GIH	.052 In/Sec	.015 G-s
COH	.114 In/Sec	.028 G-s
STD5	- Stand 5	(18-Jun-20)
	OVERALL LEVEL	1K-20KHz
MOH	.036 In/Sec	.079 G-s
MIH	.094 In/Sec	.029 G-s
MIA	.079 In/Sec	.035 G-s
GIA	.042 In/Sec	.0044 G-s
GIH	.034 In/Sec	.0034 G-s
GOH	.059 In/Sec	.054 G-s
COH	.582 In/Sec	.023 G-s
STD6	- Stand 6	(18-Jun-20)
	OVERALL LEVEL	1K-20KHz
MOH	.039 In/Sec	.058 G-s
MIH	.035 In/Sec	.068 G-s
MIA	.091 In/Sec	.054 G-s
GIA	.031 In/Sec	.0069 G-s
GIH	.025 In/Sec	.0076 G-s
GOH	.065 In/Sec	.063 G-s
COH	.085 In/Sec	.081 G-s
STD7	- Stand 7	(18-Jun-20)
	OVERALL LEVEL	1K-20KHz
MOH	.046 In/Sec	.052 G-s
MIH	.062 In/Sec	.078 G-s
MIA	.052 In/Sec	.217 G-s
GIA	.039 In/Sec	.0071 G-s
GIH	.029 In/Sec	.023 G-s
GOH	.103 In/Sec	.032 G-s
COH	.377 In/Sec	.063 G-s
STD8	- Stand 8	(18-Jun-20)
	OVERALL LEVEL	1K-20KHz
MOH	.033 In/Sec	.023 G-s
MIH	.041 In/Sec	.054 G-s
MIA	.049 In/Sec	.048 G-s
GIA	.035 In/Sec	.023 G-s
GIH	.024 In/Sec	.014 G-s
COH	.116 In/Sec	.077 G-s
STD9	- Stand 9	(18-Jun-20)
	OVERALL LEVEL	1K-20KHz
MOH	.033 In/Sec	.070 G-s
MIH	.129 In/Sec	.105 G-s
MIA	.055 In/Sec	.067 G-s
GIA	.105 In/Sec	.0085 G-s
GIH	.053 In/Sec	.148 G-s
COH	.172 In/Sec	.358 G-s
STD10	- Stand 10	(18-Jun-20)
	OVERALL LEVEL	1K-20KHz
MOH	.036 In/Sec	.034 G-s
MIH	.048 In/Sec	.045 G-s
MIA	.058 In/Sec	.028 G-s
GIA	.039 In/Sec	.149 G-s
GIH	.039 In/Sec	.077 G-s
COH	.129 In/Sec	.039 G-s
STD11	- Stand 11	(18-Jun-20)
	OVERALL LEVEL	1K-20KHz
MOH	.021 In/Sec	.039 G-s
MIH	.027 In/Sec	.029 G-s

	MIA	.050 In/Sec	.088 G-s
	GIA	.076 In/Sec	.038 G-s
	GIH	.055 In/Sec	.228 G-s
	GOH	.039 In/Sec	.114 G-s
	COH	.129 In/Sec	.026 G-s
STD12	- Stand 12	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz	
	MOH	.027 In/Sec	.074 G-s
	MIH	.025 In/Sec	.121 G-s
	MIA	.053 In/Sec	.194 G-s
	COH	.124 In/Sec	.052 G-s
STD13	- Stand 13	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz	
	MOH	.060 In/Sec	.149 G-s
	MIH	.100 In/Sec	.082 G-s
	MIA	.097 In/Sec	.102 G-s
	GIA	.042 In/Sec	.044 G-s
	GIH	.028 In/Sec	.052 G-s
	GOH	.048 In/Sec	.017 G-s
	COH	.369 In/Sec	.402 G-s
STD14	- Stand 14	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz	
	MOH	.117 In/Sec	.286 G-s
	MIH	.103 In/Sec	.152 G-s
	MIA	.099 In/Sec	.050 G-s
	GIA	.044 In/Sec	.055 G-s
	GIH	.031 In/Sec	.019 G-s
	GOH	.029 In/Sec	.064 G-s
	COH	.423 In/Sec	.158 G-s
STD15	- Stand 15	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz	
	MOH	.058 In/Sec	.252 G-s
	MIH	.076 In/Sec	.501 G-s
	MIA	.051 In/Sec	.166 G-s
	GIA	.035 In/Sec	.071 G-s
	GIH	.052 In/Sec	.366 G-s
STD16	- Stand 16	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz	
	MOH	.043 In/Sec	.119 G-s
	MIH	.045 In/Sec	.257 G-s
	MIA	.050 In/Sec	.147 G-s
	GIA	.085 In/Sec	.017 G-s
	GIH	.049 In/Sec	.023 G-s
	GOH	.039 In/Sec	.019 G-s
	COH	.190 In/Sec	.102 G-s
NORTH AC	- NORTH AIR COMPRESSOR QUINCY	(18-Jun-20)	
	OVERALL LEVEL	1 - 20 KHz	
	MOH	.143 In/Sec	.167 G-s
	MIH	.138 In/Sec	.400 G-s
	MIA	.263 In/Sec	.017 G-s
	OVERALL LEVEL	1K-20KHz	
	CIA	.243 In/Sec	.550 G-s
	CIH	.218 In/Sec	.413 G-s
	COH	.196 In/Sec	.523 G-s
SOUTH AC	- SOUTH AIR COMPRESSOR QUINCY	(18-Jun-20)	
	OVERALL LEVEL	1 - 20 KHz	
	MOH	.073 In/Sec	.960 G-s
	MIH	.158 In/Sec	.383 G-s
	MIA	.102 In/Sec	.362 G-s
	OVERALL LEVEL	1K-20KHz	
	CIA	.192 In/Sec	.458 G-s
	CIH	.183 In/Sec	.373 G-s
	COH	.235 In/Sec	.649 G-s

Database: nucorja9.rbm
Station: Roll Mill Utilities

MEASUREMENT POINT	OVERALL LEVEL	HFD / VHFD
-----	-----	-----
HYDPMP1 - Hydraulic Pump East	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.176 In/Sec	.147 G-s
MIH	.433 In/Sec	.169 G-s
PIV	.240 In/Sec	1.103 G-s
HYDPMP3 - Hydraulic Pump West	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.119 In/Sec	.345 G-s
MIH	.292 In/Sec	.335 G-s
PIV	.305 In/Sec	3.535 G-s
DESFAN - Desolution Fan	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.018 In/Sec	.081 G-s
MIH	.027 In/Sec	.040 G-s
COMFAN - Combustion Air Fan	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.149 In/Sec	.171 G-s
MIH	.115 In/Sec	.268 G-s
MIA	.074 In/Sec	.161 G-s
FIH	.083 In/Sec	.131 G-s
FOH	.109 In/Sec	1.169 G-s
EJCFAN - Ejector Air Fan	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.088 In/Sec	.617 G-s
MIH	.085 In/Sec	1.421 G-s
MIA	.454 In/Sec	1.175 G-s
FIH	.065 In/Sec	1.925 G-s
FOH	.062 In/Sec	1.064 G-s
COLPMP2 - Furnace Cooling Pump center	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.256 In/Sec	.331 G-s
MIH	.152 In/Sec	.481 G-s
MIA	.132 In/Sec	.110 G-s
FCTSOUTH - Furnace CT Drive South	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.350 In/Sec	.081 G-s
MIH	.204 In/Sec	.157 G-s
MIA	.180 In/Sec	.015 G-s
FCTNORTH - Furnace CT Drive North	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.278 In/Sec	.103 G-s
MIH	.143 In/Sec	.065 G-s
MIA	.154 In/Sec	.0060 G-s
SCLPMP1 - Scale Pit Pump South	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.104 In/Sec	.312 G-s
MOV	.096 In/Sec	.428 G-s
MIV	.055 In/Sec	.106 G-s
MIH	.078 In/Sec	.122 G-s
MIA	.064 In/Sec	.058 G-s
CTWTR1 - CT Pump East/Middle Pump	(18-Jun-20)	
	OVERALL LEVEL	1K-20KHz
MOH	.084 In/Sec	.487 G-s
MIH	.117 In/Sec	.260 G-s


MIA	.054 In/Sec	.112 G-s
MILWTR3 - Mill Water Pump West (18-Jun-20)		
	OVERALL LEVEL	1K-20KHz
MOH	.070 In/Sec	.335 G-s
MIH	.049 In/Sec	.676 G-s
MIA	.029 In/Sec	.357 G-s
MILWTR1 - Mill Water Pump East (18-Jun-20)		
	OVERALL LEVEL	1K-20KHz
MOH	.100 In/Sec	.223 G-s
MIH	.050 In/Sec	.323 G-s
MIA	.039 In/Sec	.100 G-s
EASTBOOST - East Booster Pump Small (18-Jun-20)		
	OVERALL LEVEL	1K-20KHz
MOH	.217 In/Sec	.0010 G-s
MIH	.200 In/Sec	.0043 G-s
MIA	.135 In/Sec	.0023 G-s

Clarification Of Vibration Units:

Acc	-->	G-s	RMS
Vel	-->	In/Sec	PK

As always, it has been a pleasure to NUCOR Steel Flowood, MS. If there are any comments or questions, do not hesitate to contact us.

Sincerely,



ISO Certified Vibration Analyst, Category III



QualiTest® Diagnostics

Cell: 901-486-4565

Email: kwilliam@gohispeed.com