



7030 Ryburn Dr. Millington, TN

Phone: (901) 873-5300

Fax: (901) 873-5301

[www.gohispeed.com](http://www.gohispeed.com)

June 12, 2023

Mason Shelley  
UniPres  
Forest, MS

Mason,

All specified electrical equipment was scanned with a FLIR T865 infrared Camera. We found all specified panels to be in satisfactory condition and have no defects to report at this time. Please let us know if there are any questions or concerns. As always, it has been a pleasure to serve Unipres Forest, MS.

Sincerely,

A handwritten signature in black ink that reads 'Kevin W. Maxwell'.

ISO Certified Vibration Analyst, Category III  
ISO-ITC Certified Level II Infrared Thermographer



**QualiTest® Diagnostics**

Cell: 901-486-4565

Email: [kymaxwell@gohispeed.com](mailto:kymaxwell@gohispeed.com)