

02-J15T0339NPI

Hi-Speed Industrial Service 7030 Ryburn Dr Millington, Tn 38053 901-873-5300

> FolderID: 103310 FormID: 21189491

AC Inspection as Found Phelps Fan Manufacturing Co. 10701 Interstate 30

Little Rock, AR 72209

Serial Number:

AC Inspection - Rev. 2

MOTOR SHOP LR Location:

Description:125HP SIEMENS

Hi-Speed Job Number:	103310
Manufacturer:	Siemens
Product Number:	TYPE: 6B103
Serial Number:	02-J15T0339NPI
HP/kW:	125 (HP)
RPM:	1785 (RPM)
Frame:	444L
Voltage:	460
Current:	143 (Amps)
Phase:	Three
Hz:	60 (Hz)
Enclosure:	TEFC
# of Leads:	6
J-box Included:	None
Coupling/Sheave:	None
Date Received:	08/02/2024
Bearing RTDs:	No
Stator RTDs:	No
Repair Stage:	Final
Rewind:	No
Shaft Machined Fit Repairs Required:	No
Bearing Housing Machined Fit Repairs Required:	No
Heaters:	No
Winding Type :	Random Wound
Bearing Type:	Rolling Element

Priorities Found: **a** 2 - High

13 - Good

Overall Condition

0

Report Date

08/02/2024



3. Photos of all six sides of the machine.

























4. Describe the Overall Condition of the Equipment as Received Serviceable

	5.	Report Date [COPY]	08/02/2024	
In	itial I	Mechanical/Electrical		ō
	6.	Does Shaft Turn Freely?	(Y) Yes	
	7.	Does the shaft require T.I.R in Lathe to identify additional repairs?	(No) No	
	8.	Does Shaft Have Visible Damage?	(No) No	
	9.	Assembled Shaft Runout	0.002 Inches	
	10.	Assembled Shaft End Play	0 inches	
	11.	Air Gap Variation <10%		
	12.	Lead Condition	(P) Pass	
	13.	Lead Length	15 Inches	
	14.	Does it have Lugs?, If so what is the Stud Size?	(No) No	
	15.	Lead Numbers	1-3	
	16.	Frame Condition	pass	
	17.	Fan Condition	(P) Pass	P116



18. Broken or Missing Components

1 ea. DE mount bolt.

Initial Electrical Inspection





20. Winding Resistance

1-2

2-3

1-3

P20



21. Perform Surge Test

(P) Pass

P57



22. Number of Stator Slots

48

23. Stator Condition

excessive grease but tests good

24. Stator Thermistors/Ohms

25. Stator Overloads/Ohms

Mechanical Inspection

0









	1	Drive End Bearing Qty.	28.
	(Roller) Roller Bearing	Drive End Bearing Type	29.
	(Grease) Grease Lubricated	Drive End Lubrication Type	30.
		Drive End Bearing Insulation or Grounding Device?	31.
	none	Drive End Wavy Washer/Snap-Ring Other Retention Device?	32.
	worn.	Drive End Bearing Condition	33.
	FAG	Opposite Drive End Bearing Brand	34.
P100		Opposite Drive End Rearing Number-	35



36. Opposite Drive End Bearing Qty.

1





38.	Opposite Drive End Lubrication Type	(Grease) Grease Lubricated	
39.	Opposite Drive End Bearing Insulation or Grounding Device?	none	
40.	Opposite Drive End Wavy Washer/Snap-Ring Other Retention Device?	snap ring	
41.	Opposite Drive End Bearing Condition	worn with signs of frosting	
42	Drive End Seal		P121

Dry rotted. Dust seal



43. Opposite Drive End SealDust seal

Rotor Inspection



40	Cinnetons of Technicies that Disease while Mateu	Tamanaa Halland	
	Bearings/recondition		
48.	List the Parts needed for the Repair Below		
47.	Rotor Condition	pass	
46.	Number of Rotor Bars	36	
45.	Growler Test	(Pass) Pass	

49. Signature of Technician that Disassembled Motor

Terrence. Holland

Mecha	nical Fits- Rotor		
50.	Shaft Runout		0.003 inches
51.	Rotor Runout		
	Drive End Bearing Fit	Rotor Body	Opposite Drive End Bearing
52.	Coupling Fit Closest to Bearing H	ousing	
	0 Degrees	90 Degrees	120 Degrees
53.	Coupling Fit Closest to the end of	the Shaft	
	0 Degrees	60 Degrees	120 Degrees
54.	Drive End Bearing Shaft Fit		
	0 Degrees	60 Degrees	120 Degrees
	3.5441	3.5441	3.5441
5 5.	Drive End Bearing Shaft Fit Cond	ition	(P) Pass
56.	Opposite Drive End Bearing Shafe	t Fit	
	0 Degrees	60 Degrees	120 Degrees
	3.15	3.15	3.1499
5 7.	Opposite Drive End Bearing Shafe	t Fit Condition	(P) Pass
58.	Shaft Air Seal Fits		
	Drive End Air Seal	Opposite Drive End Air Seal	

Med	chai	nical Fits- Bearing Housings		ō	
Ę	59.	Drive End - Endbell Bearing Fit			
		0 Degrees	60 Degrees	120 Degrees	
		7.4805	7.4804	7.4806	
• 6	60.	Drive End - Endbell Bearing Fit (Condition	(P) Pass	
6	61.	Opposite Drive End - Endbell Be	aring Fit		
		0 Degrees	60 Degrees	120 Degrees	
		6.693	6.6931	6.6932	
• 6	62.	Opposite Drive End - Endbell Be	aring Fit Condition	(P) Pass	
6	63.	Bearing Cap Condition			P52
		Drive End Bearing Cap	Opposite Drive End Bearing Cap		
		pass	pass		
	00				
6	64.	End Bell Air Seal Fits			
		Drive End Air Seal	Opposite Drive End Air Seal		
(65.	List Machine Work Needed Belo	W		
6	66.	Technician		Terrence Holland	
	/.	L - 4	1/11/		
-		Witness: TLH			
		ause of Failure			
6	67.	Failure locations			
		Bearings.			
(68.	Root cause of failure Contaminated bearing grease. Mo	otor was over greased. ODE, bearing sho	owed signs of misalignment	
D		ia Palanas Banart			

Dynamic Balance Report

69. Rotor Weight and Balance Grade

Rotor Weight Balance Grade

P11

Drive End

Opposite Drive End



71. Final Balance Readings

P27

Drive End

Opposite Drive End



72. Technician

Terrence Holland

Assembly

73. QC Check All Parts for Cleanliness Prior to Assembly

Terrence Holland

J =













75. Final Insulation Resistance Test Megohms P31



76.	Assembled Shaft Endplay		0 inches	S
77.	Assembled Shaft Runout		0.001 inches	S
78.	Test Run Voltage			P56
	Volts	Volts	Volts	
	457	454	460	



79. Test Run Amperage

Amps
Amps
Amps
47.1
43.8
P65

44.3



80.	80. Drive End Vibration Readings - Inches Per Second		
	Horizontal	Vertical	Axial

81. Opposite Drive End Vibration Readings - Inches Per Second Horizontal Vertical Axial 82. Ambient Temperature - Fahrenheit 83. Drive End Bearing Temps - Fahrenheit 5 Minutes 10 Minutes 15 Minutes 84. Opposite Drive End Bearing Temps - Fahrenheit 5 Minutes 10 Minutes 15 Minutes

85. Document Final Condition with Pictures after paint

86. Final Pics and QC Review Terrence Holland P132



Witness RW















