

FolderID: 103442 FormID: 21428152



AC Inspection as Found ARKANSAS INDUSTRIAL MACHINERY

3804 N. NONA ST **NORTH LITTLE ROCK, AR 72118**

AC Inspection - Rev. 2 Location: Shop Serial Number: 68690303J Description: 184/245 MARATHON

Hi-Speed Job Number:	103442
Manufacturer:	Marathon
Product Number:	TYPE: HK-315M-4
Serial Number:	68690303J
HP/kW:	184 (HP)
RPM:	1780 (RPM)
Frame:	315M
Voltage:	460
Current:	276 (Amps)
Phase:	Three
Hz:	60 (Hz)
Service Factor:	1.00
Enclosure:	TEFC
# of Leads:	6
J-box Included:	Half
Coupling/Sheave:	None
Date Received:	08/28/2024
Bearing RTDs:	No
Stator RTDs:	No
Repair Stage:	Final
Rewind:	No
Shaft Machined Fit Repairs Required:	No
Bearing Housing Machined Fit Repairs Required:	Yes
Heaters:	No
Winding Type :	Random Wound
Bearing Type:	Rolling Element

Priorities Found: **2 - High**



15 - Good

Overall Condition

Report Date

08/27/2024

0





3. Photos of all six sides of the machine.























Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.



















4. Describe the Overall Condition of the Equipment as Received Serviceable

	5. Report Date [COPY]		08/27/2024	
Ir	nitial	Mechanical/Electrical	Ō	
	6.	Does Shaft Turn Freely?	(Y) Yes	
	7.	Does the shaft require T.I.R in Lathe to identify additional repairs?	(No) No	
	8.	Does Shaft Have Visible Damage?	(No) No P	26



9.	Assembled Shaft Runout	0.001 Inches
10.	Assembled Shaft End Play	0 inches
11.	Air Gap Variation <10%	
12.	Lead Condition	(P) Pass



14. Does it have Lugs?, If so what is the Stud Size?



P94



15. Lead Numbers P98

U1-V1-W1 U2-V2-W2





16. Frame Condition pass

17. Fan Condition
(P) Pass
P116




18. Broken or Missing Components

top connection box cover

Initial Electrical Inspection





20. Winding Resistance P20

1-2 1-3 2-3



21. Perform Surge Test (P) Pass

22. Number of Stator Slots 72

23. Stator Condition pass

24. Stator Thermistors/Ohms

25. Stator Overloads/Ohms



Mechanical Inspection

0

P97



27. Drive End Bearing Number-

6319 C3

P32



28. Drive End Bearing Qty.

(Ball) Ball Bearing

P51

29. Drive End Bearing Type





30.	Drive End Lubrication Type	(Grease) Grease Lubricated	
31.	Drive End Bearing Insulation or Grounding Device?	none	
32.	Drive End Wavy Washer/Snap-Ring Other Retention Device?	none	
33.	Drive End Bearing Condition	replace	
34	Opposite Drive End Rearing Brand		P93



35. Opposite Drive End Bearing Number-







36.	Opposite Drive End Bearing Qty.	1	
37.	Opposite Drive End Bearing Type	(Ball) Ball Bearing	
38.	Opposite Drive End Lubrication Type	(Grease) Grease Lubricated	
39.	Opposite Drive End Bearing Insulation or Grounding Device?	none	
40.	Opposite Drive End Wavy Washer/Snap-Ring Other Retention Device?	snap ring	
41.	Opposite Drive End Bearing Condition	replace	
42.	Drive End Seal		
43.	Opposite Drive End Seal		

Rotor Inspection			
44.	Rotor Type/Material	(Squirrel Aluminum) Squirrel Cage Aluminum Die Cast	
45.	Growler Test	(Pass) Pass	
46.	Number of Rotor Bars	62	
47.	Rotor Condition	pass	
48.	List the Parts needed for the Repair Below		
	Sleeve ODE housing fit		

49. Signature of Technician that Disassembled Motor **Terrence Holland**

Λc	char	nical Fits- Rotor		
VIE	50.	Shaft Runout		0.001 inches
				0.001 menes
	51.		Datar Dady	Opposite Drive End Bearing
		Drive End Bearing Fit	Rotor Body	Opposite Drive End Bearing
_	52.	Coupling Fit Closest to Bearing Ho	ousing	
,	JZ.	0 Degrees	90 Degrees	120 Degrees
		3.15	3.1501	3.1501
_	53.	Coupling Fit Closest to the end of		3.1301
,	55.			120 Dogroop
		0 Degrees 3.1501	60 Degrees 3.15	120 Degrees 3.1501
	E A		3.15	3.1301
,	54.	Drive End Bearing Shaft Fit	CO Doggood	120 Degrees
		0 Degrees	60 Degrees	120 Degrees
		3.7407	3.7406	3.7407
<i>y</i>		Drive End Bearing Shaft Fit Condi		(P) Pass
ji	56.	Opposite Drive End Bearing Shaft		420 Dagge
		0 Degrees	60 Degrees	120 Degrees
_		3.7409	3.741	3.7409
)		Opposite Drive End Bearing Shaft	Fit Condition	(P) Pass
	58.	Shaft Air Seal Fits		
		Drive End Air Seal	Opposite Drive End Air Seal	
Иe		nical Fits- Bearing Housings		
	59.	Drive End - Endbell Bearing Fit		
		0 Degrees	60 Degrees	120 Degrees
		7.8746	7.8748	
		Drive End - Endbell Bearing Fit Co		(P) Pass
	61.	Opposite Drive End - Endbell Bear		
		0 Degrees	60 Degrees	120 Degrees
		7.8745	7.8756	7.8752
	-	Verified by machinist.		
	62.	Opposite Drive End - Endbell Bear	ring Fit Condition	(F) Fail
	•	Oval shape. Verified by machinist.		
	63.	Bearing Cap Condition		
		Drive End Bearing Cap	Opposite Drive End Bearing Cap	
		pass	pass	
	64.	End Bell Air Seal Fits		
		Drive End Air Seal	Opposite Drive End Air Seal	
	65	List Machine West New Jeel D.		
	65.	List Machine Work Needed Below		
	00	ODE housing fit		—
	66.	Technician	, ,,,	Terrence Holland
		Colonia de la Co	/ ///	
		1)/		
	45	7]/		
	/-	T 4		

Root Cause of Failure



67. Failure locations

ODE housing fit.

68. Root cause of failure P18

Contaminated/hardened grease in both bearings. ODE housing fit out of tolerance. DE bearing shows signs of frosting. Recommend aegis shaft grounding ring.



Dynamic Balance Report

69. Rotor Weight and Balance Grade

Rotor Weight Balance Grade

70. Initial Balance Readings

Drive End Opposite Drive End

71. Final Balance Readings

Drive End Opposite Drive End

72. Technician

Mechanical Fits- Bearing Housings - Post Repair

73. Drive End - Endbell Bearing Fit Post Repair

0 Degrees 60 Degrees 120 Degrees

74. Opposite Drive End - Endbell Bearing Fit Post Repair

0 Degrees 60 Degrees 120 Degrees

75. Bearing Cap Condition Post Repair

Drive End Bearing Cap Opposite Drive End Bearing Cap

76. End Bell Air Seal Fits Post Repair

Drive End Air Seal Opposite Drive End Air Seal

77. End Bell Repair Sign-off

Assembly

- 78. QC Check All Parts for Cleanliness Prior to Assembly
- 79. Photograph All Major Components prior to assembly
- 80. Final Insulation Resistance Test
- 81. Assembled Shaft Endplay

82.	Assembled Shaft Runout			
83.	Test Run Voltage			
	Volts	Volts	Volts	
84.	Test Run Amperage			
	Amps	Amps	Amps	
85.	Drive End Vibration Readings - I	nches Per Second		
	Horizontal	Vertical	Axial	
86.	Opposite Drive End Vibration Readings - Inches Per Second			
	Horizontal	Vertical	Axial	
87.	7. Ambient Temperature - Fahrenheit			
88. Drive End Bearing Temps - Fahrenheit				
	5 Minutes	10 Minutes	15 Minutes	
89.	Opposite Drive End Bearing Ten	nps - Fahrenheit		
	5 Minutes	10 Minutes	15 Minutes	
90.	Document Final Condition with P	rictures after paint		
	Final Pics and QC Review			

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.