



7030 Ryburn Dr. Millington, TN

Phone: (901) 873-5300

Fax: (901) 873-5301

[www.gohispeed.com](http://www.gohispeed.com)

February 5, 2024

Dell Power Plant  
Dell, AR

The following report is a summary of findings from the vibration survey that was performed on January 31, 2024. The report only contains defects/issues found from the survey.

**QualiTest®** uses a four step rating system for defects.

**Class I:** Defect is present, but effect on reliability is not clear; no immediate action is required. Continue to normally monitor.

**Class II:** Defect (s) present that may cause problem in long term (2-6 months). Repair during normal maintenance scheduling. Continue to monitor.

**Class III:** Defect (s) present that may cause failure in short term (less than 2 months). This should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.

**Class IV:** Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs

**Hi-Speed Industrial Service** tests and inspects industrial machinery and equipment and makes recommendations concerning maintenance and repairs based on its experience in the field of industrial repair and maintenance. The information contained herein is provided as an opinion only, not as a guaranty or warranty of the matters discussed herein.

## COOLING TOWER AREA

### Cooling Tower Fan 2 **CLASS II**




#### Observation:

Motor inboard peakvue spectral waterfall shows an increase amplitude over the past few surveys. Trend also shows some elevated overall G's

#### Recommendation:

Increased peakvue amplitudes are usually early signs of defects and or lube issue. There is some evidence of non-synchronous peaks in spectra, but velocity levels are very low at these peaks. For now, ensure motor has clean adequate amount of grease and inspect motor bearings for signs of defects.

## Cooling Tower Fan 3 **CLASS II**




### Observation:

Motor multi-point spectra shows a dominant vibration around 10 Hz. There is also some 1 x motor rpm vibration as well especially in the motor inboard axial (MIA).

### Recommendation:

Data shows a sub-synchronous vibration that is related to fan speed. Check gearbox foot bolts/structure and fan hub as time allows. Ensure all are tight.

## Cooling Tower Fan 9 **CLASS II**




### Observation:

Motor inboard axial (first plot) shows a large sub-synchronous peak (likely fan speed related) with a high 1 x motor rpm peak present as well. Motor outboard horizontal (MOH) peakvue data shows an increase in peakvue amplitude (second plot) and also shows a non-synchronous peak at 2.058 orders of rpm with harmonics present in the spectrum (third plot). This peak may be a defect frequency (BSF or ball spin frequency) of the bearing. The fourth plot is peakvue waveform data and it shows amplitude of 7.7 g's peak. Last survey this reading was 2.8 g's peak.

### Recommendation:

Vibration data suggests to check motor bearings for signs of defects and ensure lube is ok in motor bearings. Inspect all motor and gearbox fasteners Check output gearbox shaft for run out if possible and coupling/spacer shaft also. Inspect structural/base fasteners as well.

## Cooling Tower Fan 12 CLASS I




### Observation:

There appears to be a dominant vibration in the motor that is electrical in nature. This peak at 46 orders of rpm is likely related to rotor bar bass frequency. We would need the number of bars in the rotor to confirm.

### Recommendation:

The number of rotor bars would be helpful. For now, ensure motor current is equal across all phases. Ensure motor current load isn't higher than the other motors.

## Circ Water Pump 1A CLASS I




### Observation:

Motor trend plots above show overall pk velocity for each point. 1 x rpm vibration can be seen in the MOH velocity spectrum (bottom plot).

### Recommendation:

Overall, the velocity amplitudes of the motor are around average or below according to trend data. The 1 x motor rpm vibration seen in the MOH can possibly be influenced by the pump if the pump has internal issues. We are monitoring this closely.

## Circ Water Pump 1B CLASS I



### Observation:


Motor trend plots above show overall pk velocity for each point. 1 x rpm vibration with some small harmonics of rpm can be seen in the MOV velocity spectrum (bottom plot).

### Recommendation:

Amplitudes are below alarm level; however, there appears to be some slightly elevated vibration at the MOV. Spectral data at this point shows some small harmonics of rpm. This may indicate some type of mechanical looseness beginning to occur in the motor or pump. This will be monitored closely.

# GAS TURBINE UNIT 1

## LP Recirc Unit 1 **CLASS II**



### Observation:


Pump inboard horizontal trend show another increase in vibration this survey. Spectral data shows a 1 and 2 x rpm vibration mainly.

### Recommendation:

Data suggests a coupling issue, or issue with pump. Check pump coupling for wear and check pump shaft for run out as time allows.



## Boiler Feed Water Pump 1B CLASS I




### Observation:

MOH spectral waterfall show an increase in  $\frac{1}{2}$  rpm harmonics as compared to last reading in November 2023.


### Recommendation:

Overall amplitudes are slightly lower in the motor; however, the  $\frac{1}{2}$  harmonics in the spectrum are concerning considering these are sleeved bearings. We will continue to monitor this closely.

## Vacuum Pump 2 **CLASS II**



## STG Hydraulic Pump 1 **CLASS III**



### Observation:

Multiple harmonics 3.09 orders can be seen in the MIH spectral data. Trend data shows an increase in overall amplitude in G's. Waveform also shows high g's with pk-pk amplitude of 16 g's.

### Recommendation:

Motor data suggests bearing defects in the motor. Pump may also have some internal wear. Inspect/replace soon.

Abbreviated Last Measurement Summary  
\*\*\*\*\*

Database: AECI Dell Power Plant.rbm  
Area: Cooling Tower

MEASUREMENT POINT	OVERALL LEVEL	HFD / VHFD
-----	-----	-----
CTW1 - Cooling Tower Fan 1	(31-Jan-24)	
	OVERALL LEVEL	1K-20kHz
MOH	.202 In/Sec	1.238 G-s
MOP	.228 G-s	
MOV	.194 In/Sec	.876 G-s
MIH	.180 In/Sec	.661 G-s
MIP	.248 G-s	
MIV	.237 In/Sec	.606 G-s
MIA	.258 In/Sec	.400 G-s
CTW2 - Cooling Tower Fan 2	(31-Jan-24)	
	OVERALL LEVEL	1K-20kHz
MOH	.381 In/Sec	1.787 G-s
MOP	.625 G-s	
MOV	.203 In/Sec	1.751 G-s
MIH	.236 In/Sec	2.534 G-s
MIP	1.525 G-s	
MIV	.210 In/Sec	2.545 G-s
MIA	.293 In/Sec	1.862 G-s
CTW3 - Cooling Tower Fan 3	(31-Jan-24)	
	OVERALL LEVEL	1K-20kHz
MOH	.175 In/Sec	1.063 G-s
MOP	.244 G-s	
MOV	.329 In/Sec	.771 G-s
MIH	.242 In/Sec	.596 G-s
MIP	.268 G-s	
MIV	.356 In/Sec	.800 G-s
MIA	.461 In/Sec	1.052 G-s
CTW4 - Cooling Tower Fan 4	(31-Jan-24)	
	OVERALL LEVEL	1K-20kHz
MOH	.340 In/Sec	.833 G-s
MOP	.231 G-s	
MOV	.395 In/Sec	1.186 G-s
MIH	.327 In/Sec	.821 G-s
MIP	.268 G-s	
MIV	.348 In/Sec	.820 G-s
MIA	.283 In/Sec	.515 G-s
CTW5 - Cooling Tower Fan 5	(31-Jan-24)	
	OVERALL LEVEL	1K-20kHz
MOH	.271 In/Sec	1.024 G-s
MOP	.252 G-s	
MOV	.239 In/Sec	1.046 G-s
MIH	.254 In/Sec	1.773 G-s
MIP	.240 G-s	
MIV	.214 In/Sec	.769 G-s
MIA	.312 In/Sec	.763 G-s
CTW6 - Cooling Tower Fan 6	(31-Jan-24)	
	OVERALL LEVEL	1K-20kHz
MOH	.236 In/Sec	1.664 G-s
MOP	.556 G-s	
MOV	.222 In/Sec	1.080 G-s
MIH	.281 In/Sec	1.076 G-s
MIP	.288 G-s	
MIV	.248 In/Sec	1.673 G-s
MIA	.373 In/Sec	.909 G-s

CTW7	- Cooling Tower Fan 7	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.133 In/Sec	1.229 G-s
MOP	.626 G-s	
MOV	.257 In/Sec	.946 G-s
MIH	.148 In/Sec	1.563 G-s
MIP	.826 G-s	
MIV	.205 In/Sec	1.161 G-s
MIA	.298 In/Sec	1.038 G-s
CTW8	- Cooling Tower Fan 8	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.305 In/Sec	1.588 G-s
MOP	.262 G-s	
MOV	.205 In/Sec	1.277 G-s
MIH	.281 In/Sec	1.647 G-s
MIP	.349 G-s	
MIV	.214 In/Sec	.897 G-s
MIA	.497 In/Sec	.668 G-s
CTW9	- Cooling Tower Fan 9	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.447 In/Sec	2.977 G-s
MOP	.819 G-s	
MOV	.258 In/Sec	1.718 G-s
MIH	.270 In/Sec	1.975 G-s
MIP	.339 G-s	
MIV	.337 In/Sec	1.470 G-s
MIA	.322 In/Sec	1.259 G-s
CTW10	- Cooling Tower Fan 10	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.155 In/Sec	.253 G-s
MOP	.124 G-s	
MOV	.096 In/Sec	.284 G-s
MIH	.163 In/Sec	.552 G-s
MIP	.336 G-s	
MIV	.102 In/Sec	.349 G-s
MIA	.133 In/Sec	.345 G-s
CTW11	- Cooling Tower Fan 11	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.126 In/Sec	.357 G-s
MOP	.152 G-s	
MOV	.098 In/Sec	.332 G-s
MIH	.137 In/Sec	.791 G-s
MIP	.430 G-s	
MIV	.068 In/Sec	.598 G-s
MIA	.115 In/Sec	1.301 G-s
CTW12	- Cooling Tower Fan 12	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.199 In/Sec	1.399 G-s
MOP	.613 G-s	
MOV	.312 In/Sec	3.784 G-s
MIH	.210 In/Sec	2.407 G-s
MIP	.177 G-s	
MIV	.204 In/Sec	1.642 G-s
MIA	.256 In/Sec	.914 G-s
3CW-P-001	- Circ Water Pump 1A	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.417 In/Sec	.241 G-s
MOP	.111 G-s	
MOV	.262 In/Sec	.170 G-s
MIH	.229 In/Sec	.065 G-s
MIP	.033 G-s	
MIV	.080 In/Sec	.086 G-s
MIA	.043 In/Sec	.161 G-s

3CW-P-002	- Circ Water Pump 1B	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.131 In/Sec	.305 G-s
MOP	.179 G-s	
MOV	.257 In/Sec	.186 G-s
MIH	.033 In/Sec	.091 G-s
MIP	.047 G-s	
MIV	.152 In/Sec	.135 G-s
MIA	.044 In/Sec	.440 G-s

LFAA2	- LFAA 1B	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.051 In/Sec	.468 G-s
MOP	.290 G-s	
MOV	.046 In/Sec	.603 G-s
MIH	.082 In/Sec	.452 G-s
MIP	.494 G-s	
MIV	.061 In/Sec	.486 G-s
MIA	.066 In/Sec	.695 G-s
	OVERALL LEVEL	1K-20KHz
PIH	.025 In/Sec	.165 G-s
PIP	.077 G-s	

Area: UNIT 1

MEASUREMENT POINT	OVERALL LEVEL	HFD / VHFD
-----	-----	-----
LP #1	- LP recirc unit #1	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.100 In/Sec	.302 G-s
MOP	.086 G-s	
MOV	.181 In/Sec	.299 G-s
MIH	.079 In/Sec	.765 G-s
MIP	.356 G-s	
MIV	.123 In/Sec	.589 G-s
MIA	.227 In/Sec	.604 G-s
	OVERALL LEVEL	1K-20KHz
PIH	.768 In/Sec	.465 G-s
PIP	.316 G-s	
PIV	1.284 In/Sec	.358 G-s
POH	.240 In/Sec	.247 G-s
POP	.090 G-s	
POV	.649 In/Sec	.345 G-s
POA	.731 In/Sec	.505 G-s

1FD-P-001B	- Boiler Feed Water 1B	(31-Jan-24)
	OVERALL LEVEL	1K-20KHz
MOH	.086 In/Sec	.389 G-s
MOP	.066 G-s	
MOV	.104 In/Sec	.014 G-s
MIH	.102 In/Sec	.149 G-s
MIP	.034 G-s	
MIV	.162 In/Sec	.028 G-s
MIA	.121 In/Sec	.086 G-s
	OVERALL LEVEL	1K-20kHz
NIA	.062 In/Sec	.202 G-s
NIH	.070 In/Sec	.171 G-s
NIV	.040 In/Sec	.169 G-s
NOV	.051 In/Sec	.081 G-s
NOH	.050 In/Sec	.059 G-s
NOA	.115 In/Sec	.421 G-s
	OVERALL LEVEL	1K-20KHz
BFA	.024 In/Sec	.162 G-s
PIH	.067 In/Sec	.181 G-s
PIV	.090 In/Sec	.136 G-s
POV	.090 In/Sec	.084 G-s
POH	.087 In/Sec	.108 G-s

CT1	- CT Lube Oil Pump 1	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.076 In/Sec	.193 G-s
MOP	.051 G-s	
MOV	.044 In/Sec	.368 G-s
MIH	.054 In/Sec	.059 G-s
MIP	.022 G-s	
MIV	.038 In/Sec	.166 G-s
MIA	.045 In/Sec	.148 G-s

CTHYD !1	- CT Hyd Pump 2	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.072 In/Sec	.075 G-s
MOP	.017 G-s	
MOV	.121 In/Sec	.161 G-s
MIH	.064 In/Sec	.530 G-s
MIP	.272 G-s	
MIV	.120 In/Sec	.161 G-s
MIA	.070 In/Sec	.370 G-s

Area: UNIT 2

MEASUREMENT POINT	OVERALL LEVEL	HFD / VHFD
-----	-----	-----

LP #2	- LP recirc unit #2	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.159 In/Sec	.677 G-s
MOP	.235 G-s	
MOV	.111 In/Sec	.812 G-s
MIH	.136 In/Sec	.819 G-s
MIP	.490 G-s	
MIV	.132 In/Sec	.848 G-s
MIA	.179 In/Sec	1.388 G-s
	OVERALL LEVEL	1K-20KHz
PIH	.157 In/Sec	1.159 G-s
PIP	.777 G-s	
PIV	.105 In/Sec	.781 G-s
POH	.133 In/Sec	.965 G-s
POP	.591 G-s	
POV	.166 In/Sec	1.502 G-s
POA	.122 In/Sec	2.410 G-s

2FD-P-002B	- Boiler Feed Water 2B	(31-Jan-24)
	OVERALL LEVEL	1K-20KHz
MOH	.020 In/Sec	.957 G-s
MOP	.562 G-s	
MOV	.062 In/Sec	.458 G-s
MIH	.056 In/Sec	1.283 G-s
MIP	.564 G-s	
MIV	.030 In/Sec	.347 G-s
MIA	.041 In/Sec	1.223 G-s
	OVERALL LEVEL	1K-20kHz
NIA	.104 In/Sec	.535 G-s
NIH	.044 In/Sec	.322 G-s
NIV	.030 In/Sec	.265 G-s
NOV	.022 In/Sec	.185 G-s
NOH	.052 In/Sec	.123 G-s
NOA	.073 In/Sec	.386 G-s
	OVERALL LEVEL	1K-20KHz
BFA	.042 In/Sec	.337 G-s
PIH	.084 In/Sec	.276 G-s
PIV	.125 In/Sec	.270 G-s
POV	.088 In/Sec	.195 G-s
POH	.131 In/Sec	.140 G-s

CT1	- CT Lube Oil Pump 1	(31-Jan-24)
	OVERALL LEVEL	1K-20kHz
MOH	.069 In/Sec	.123 G-s

MOP	.036 G-s	
MOV	.056 In/Sec	.042 G-s
MIH	.038 In/Sec	.063 G-s
MIP	.022 G-s	
MIV	.044 In/Sec	.085 G-s
MIA	.122 In/Sec	.085 G-s

CTHYD ! - CT Hyd Pump 1 (31-Jan-24)

	OVERALL LEVEL	1K-20kHz
MOH	.075 In/Sec	.258 G-s
MOP	.069 G-s	
MOV	.073 In/Sec	.179 G-s
MIH	.026 In/Sec	.384 G-s
MIP	.178 G-s	
MIV	.047 In/Sec	.765 G-s
MIA	.043 In/Sec	.422 G-s

ABF - Aux Boiler Fan (31-Jan-24)

	OVERALL LEVEL	1K-20kHz
MOH	.138 In/Sec	.454 G-s
MOP	.074 G-s	
MOV	.338 In/Sec	.363 G-s
MIH	.075 In/Sec	.845 G-s
MIP	.086 G-s	
MIV	.076 In/Sec	.489 G-s
MIA	.250 In/Sec	.326 G-s

Area: UNIT STEAM TURBINE

MEASUREMENT POINT	OVERALL LEVEL	HFD / VHFD
-----	-----	-----

3CW-P-003 - CCW Booster Pump 1 (31-Jan-24)

	OVERALL LEVEL	1K-20kHz
MOH	.059 In/Sec	.257 G-s
MOP	.030 G-s	
MOV	.055 In/Sec	.353 G-s
MIH	.048 In/Sec	.334 G-s
MIP	.181 G-s	
MIV	.041 In/Sec	.256 G-s
MIA	.054 In/Sec	.409 G-s
	OVERALL LEVEL	1K-20KHz
PIH	.072 In/Sec	.386 G-s
PIP	.322 G-s	
PIV	.102 In/Sec	.344 G-s
PIA	.061 In/Sec	.693 G-s

OCC-P-001 - CLosed Cooling Water 1 (31-Jan-24)

	OVERALL LEVEL	1K-20kHz
MOH	.079 In/Sec	.356 G-s
MOP	.079 G-s	
MOV	.043 In/Sec	.427 G-s
MIH	.081 In/Sec	.925 G-s
MIP	.090 G-s	
MIV	.044 In/Sec	.587 G-s
MIA	.076 In/Sec	1.109 G-s
	OVERALL LEVEL	1K-20KHz
PIH	.047 In/Sec	.597 G-s
PIP	.277 G-s	
PIV	.036 In/Sec	1.723 G-s
POH	.046 In/Sec	.723 G-s
POP	.294 G-s	
POV	.034 In/Sec	1.275 G-s
POA	.090 In/Sec	1.712 G-s

3CH-P-001A - Condensate Pump A (31-Jan-24)

	OVERALL LEVEL	1K-20kHz
MOH	.183 In/Sec	.873 G-s
MOP	.062 G-s	



MOV	.174 In/Sec	.258 G-s
MIH	.061 In/Sec	.373 G-s
MIP	.136 G-s	
MIV	.085 In/Sec	.214 G-s
MIA	.032 In/Sec	.147 G-s
	OVERALL LEVEL	1K-20KHz
PIH	.054 In/Sec	.392 G-s
PIP	.233 G-s	
PIV	.073 In/Sec	.401 G-s
PIA	.034 In/Sec	.370 G-s

3CH-P-001C - Condensate PumpC (31-Jan-24)

	OVERALL LEVEL	1K-20kHz
MOH	.355 In/Sec	1.148 G-s
MOP	.112 G-s	
MOV	.233 In/Sec	.317 G-s
MIH	.135 In/Sec	.582 G-s
MIP	.232 G-s	
MIV	.139 In/Sec	.794 G-s
MIA	.055 In/Sec	.629 G-s
	OVERALL LEVEL	1K-20KHz
PIH	.156 In/Sec	.965 G-s
PIP	.469 G-s	
PIV	.139 In/Sec	.414 G-s
PIA	.039 In/Sec	.916 G-s

3AE-P-002 - Vacuum Pump 2 (31-Jan-24)

	OVERALL LEVEL	1K-20kHz
MOH	.133 In/Sec	1.025 G-s
MOP	.197 G-s	
MOV	.161 In/Sec	.927 G-s
MIH	.190 In/Sec	.332 G-s
MIP	.157 G-s	
MIV	.230 In/Sec	1.266 G-s
MIA	.176 In/Sec	.182 G-s
	OVERALL LEVEL	1K-20KHz
PIH	.244 In/Sec	1.116 G-s
PIP	1.047 G-s	
PIV	.401 In/Sec	.390 G-s
POH	.255 In/Sec	.502 G-s
POP	.535 G-s	
POV	.443 In/Sec	1.076 G-s
POA	.195 In/Sec	.708 G-s

STG2 - STG Lube Oil Pump 2 (31-Jan-24)

	OVERALL LEVEL	1K-20kHz
MOH	.071 In/Sec	.128 G-s
MOP	.026 G-s	
MOV	.047 In/Sec	.437 G-s
MIH	.038 In/Sec	.420 G-s
MIP	.188 G-s	
MIV	.034 In/Sec	.555 G-s
MIA	.040 In/Sec	.179 G-s

STGHyd1 - STG Hyd Pump 1 (31-Jan-24)

	OVERALL LEVEL	1K-20kHz
MOH	.224 In/Sec	1.406 G-s
MOP	.876 G-s	
MOV	.162 In/Sec	1.566 G-s
MIH	.225 In/Sec	2.718 G-s
MIP	1.443 G-s	
MIV	.183 In/Sec	4.229 G-s
MIA	.170 In/Sec	1.840 G-s
	OVERALL LEVEL	1K-20KHz
PIH	.255 In/Sec	.810 G-s
PIP	.495 G-s	
PIV	.338 In/Sec	1.964 G-s
PIA	.300 In/Sec	3.353 G-s

Area: WATER PUMPS AND VACUUM PUMPS

MEASUREMENT POINT	OVERALL LEVEL	HFD / VHFD
-----		
OSW-P-001B - Service Water Pump 1B (31-Jan-24)		
	OVERALL LEVEL	1K-20kHz
MOH	.664 In/Sec	.486 G-s
MOP	.290 G-s	
MOV	.231 In/Sec	.575 G-s
MIH	.666 In/Sec	.986 G-s
MIP	.570 G-s	
MIV	.135 In/Sec	.457 G-s
MIA	.208 In/Sec	.420 G-s
	OVERALL LEVEL	1K-20KHz
PIH	.454 In/Sec	1.174 G-s
PIP	.790 G-s	
PIV	.273 In/Sec	1.035 G-s
POH	.238 In/Sec	1.041 G-s
POP	.494 G-s	
POV	.263 In/Sec	1.851 G-s
POA	.224 In/Sec	1.324 G-s


-----

Clarification Of Vibration Units:

Acc	-->	G-s	RMS
Vel	-->	In/Sec	PK

As always, it has been a pleasure to serve AECI Dell Power Plant. If there are any comments or questions, do not hesitate to contact us.

Sincerely,



Category III Vibration Analyst

Cell: 901-486-4565

Email: [kwilliam@gohispeed.com](mailto:kwilliam@gohispeed.com)