



Field Service Ticket

FolderID: 152901
FormID: 20508491

LANDMARK CO
1897 THOMAS RD
MEMPHIS, TN 38134

Performed By: **JOE SHURTZ**
Date Completed: 05/29/2024


Job Information

- | | |
|---------------------------------|--|
| 1. Hi-Speed Job Number | 152901 |
| 2. Asset Type | exhaust fan |
| 3. Make | na |
| 4. Model | na |
| 5. Serial Number | na |
| 6. Customer Asset ID/Asset Name | exhaust fan (city of Memphis asphalt plant) |

Service Call Details



- | | |
|---|----|
| 7. Service Objectives | |
| <i>Check fan and balance if needed</i> | |
| 8. Services Performed | P5 |
| <i>Checked runout on shaft, aligned sheaves, and balanced fan</i> | |



- | | |
|---------------------------------------|--|
| 9. Service Technician Recommendations | |
| <i>Touch up welds on base</i> | |

Approval Signatures

- | | |
|----------------------------------|------------|
| 10. Service Technician Signature | Joe Shurtz |
|----------------------------------|------------|

- | | |
|------------------------|---------------|
| 11. Customer Signature | Reshaud Clark |
|------------------------|---------------|