



Hi-Speed Industrial Service  
7030 Ryburn Dr  
Millington, Tn 38053  
901-873-5300

## Field Service Ticket

FolderID: 102973  
FormID: 20462843

City of Batesville (012100)  
500 Riverbank  
Batesville, AR 72501

### Job Information



- |                        |            |
|------------------------|------------|
| 1. Hi-Speed Job Number | 102973     |
| 2. Asset Type          | Water pump |
| 3. Make                | P3         |



- |                                 |        |
|---------------------------------|--------|
| 4. Model                        |        |
| 5. Serial Number                |        |
| 6. Customer Asset ID/Asset Name | Pump 1 |

### Service Call Details




- |                       |
|-----------------------|
| 7. Service Objectives |
|-----------------------|
- Check incoming power and amps on motor to make sure ok to run.*

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

8. Services Performed

P8

*Line voltages are 494, 492, 493. Amps are 75 at running speed with valves open and the second unit running. Vibration is very good. I raised the pump up one thread because it was bottomed out. Motor ran great. I put top hat back on and left the pump in the auto position as requested by the person running the station.*



9. Service Technician Recommendations

**Approval Signatures**

10. Service Technician Signature

**Trevor Hall**

11. Customer Signature

**Doug Gilbert**