



Hi-Speed Industrial Service  
7030 Ryburn Dr  
Millington, Tn 38053  
901-873-5300

## Field Service Ticket

FolderID: 103522  
FormID: 21675024

### Community Water System (12207)

299 Lakeshore Drive  
Greers Ferry, AR 72067

#### Job Information



- |                        |            |
|------------------------|------------|
| 1. Hi-Speed Job Number | 103522     |
| 2. Asset Type          | pump motor |
| 3. Make                | P3         |



- |                                 |        |
|---------------------------------|--------|
| 4. Model                        |        |
| 5. Serial Number                |        |
| 6. Customer Asset ID/Asset Name | Pump 2 |

#### Service Call Details



- |   |    |
|---|----|
| 7. Service Objectives   |    |
| <i>Laser align motor to pump</i>  |    |
| 8. Services Performed   | P8 |
| <i>Same as objective. Aligned motor to pump. New install, ended at 0 mils at coupling-good.</i> |    |




- |                                       |  |
|---------------------------------------|--|
| 9. Service Technician Recommendations |  |
|---------------------------------------|--|

#### Approval Signatures

- |                                  |             |
|----------------------------------|-------------|
| 10. Service Technician Signature | Trevor Hall |
|----------------------------------|-------------|

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

A handwritten signature in black ink, appearing to read 'B. A. McCabe', is written within a rectangular box.