



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Field Service Ticket

FolderID: 103787
FormID: 22349517

HARRISON ENERGY PARTNERS
1501 WESTPARK DR
LITTLE ROCK, AR 72204

Job Information



- | | |
|------------------------|-----------------|
| 1. Hi-Speed Job Number | 103787 |
| 2. Asset Type | Air handler fan |
| 3. Make | P3 |



- | | |
|---------------------------------|-----------------------|
| 4. Model | |
| 5. Serial Number | |
| 6. Customer Asset ID/Asset Name | 3rd floor air handler |

Service Call Details



- | | |
|--|----|
| 7. Service Objectives | |
| <i>Balance dual squirrel cage fans on one shaft</i> | |
| 8. Services Performed | P8 |
| <i>Same as objective. Balanced from 10 mils down to 0.8 and 0.9 mils</i> | |



- | | |
|---------------------------------------|--|
| 9. Service Technician Recommendations | |
|---------------------------------------|--|


Approval Signatures

- | | |
|----------------------------------|-------------|
| 10. Service Technician Signature | Trevor Hall |
|----------------------------------|-------------|

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

11. Customer Signature

George Billingsley

A handwritten signature in black ink, appearing to read "George Billingsley", is written over a light gray rectangular background.