

7030 Ryburn Dr. Millington, TN

Phone: (901) 873-5300

Fax: (901) 873-5301

www.gohispeed.com

December 2, 2024

Nucor Roll Mill Jackson-Flowood, MS

Subject: November vibration survey

Below is a summary report for the monthly Roll Mill vibration survey that was performed on 11/25-26/24. Most of the machines surveyed were found to be in good condition except for the following.

HI-SPEED uses a four-step rating system for defects.

Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue to normally monitor.

Class II: Defect (s) present that may cause problem in long term (2-6 months). Repair during normal maintenance scheduling. Continue to monitor.

Class III; Defect (s) present that may cause failure in short term (less than 2 months). This should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.

Class IV; Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs

As always, it has been a pleasure to NUCOR Steel Flowood, MS. If there are any comments or questions, do not hesitate to contact us.

Sincerely,

Kevin W. Maguell

ISO Certified Vibration Analyst, Category III



Cell: 901-486-4565 Email: kwilliam@gohispeed.com

Hi-Speed Industrial Service tests and inspects industrial machinery and equipment and makes recommendations concerning maintenance and repairs based on its experience in the field of industrial repair and maintenance. The information contained herein is provided as an opinion only, not as a guaranty or warranty of the matters discussed herein.

Defects

Roll Stand 1A

Planetary gearbox still has some vibration and noise floor that comes and goes in spectral data at the input end of the gearbox. The amplitudes and gear mesh frequencies in spectral data may be influenced some due to load and speed; however, they may also indicate low level internal wear or defects in internal components. We are continuing to monitor this closely. Rated as a **CLASS I** defect.

Roll Stand 1

Drive motor continues to have elevated DE axial vibration associated with line frequency 60 Hz and 360 HZ. (6 x line freq.). The amplitudes tend to go up and down depending on motor load and speed. This may be an SCR issue or electrical resonance. It is recommended to inspect drive components for issues. Rated as a **CLASS I** defect.

Roll Stand 2

Inboard gearbox (Int.) is showing some gear mesh vibration with sidebands of input rpm. This issue appears to come and go based on load and speed. This type of vibration is an indication of heavy tooth load or possible gear wear. Rated as a **CLASS I** defect.

Roll Stand 6

A dominant gear mesh vibration is sometimes present towards the output of the gearbox. The up and down amplitude of this peak is likely due to changes in tooth load and speed. This vibration was lower this survey. We will continue to monitor this very closely. This is rated as a **CLASS I** defect.

Roll Stand 7

Gearbox vibration was lower in amplitude this survey. Vibration data shows dominant gear mesh harmonics on outboard end of the gear casing. The up and down amplitude of this peak from month to month is likely due to changes in tooth load and machine speed. We suspect this to be possibly due to a resonant gear mesh frequency vibration and we will continue to monitor this very closely. Rated as a **CLASS I** defect.

Roll Stand 12

Motor was not in service this survey; however, the following likely still applies: Drive motor spectral data is showing some non-synchronous peaks that may be associated with bearing race defects. Typically, this issue is caused by fluting of the bearing races. This is low level at this time, and we are monitoring this closely. Rated as a **CLASS I** defect.

Roll Stand 16

Cooling fan motor has elevated vibration at the ODE. Vibration has increased this survey to near 1 ips-pk. . Inspect the cooling fan structure, fasteners, and fan wheel as scheduling allows. Rated as a **CLASS III** defect.

Furnace Cooling Tower Drive South

Motor data shows axial and radial vibration that appears to be occurring at or near 1 x motor rpm and may indicate a structural issue such as loose fasteners, weak flexible motor base. This could also be caused by a resonance or air flow turbulence in this unit. We will continue to monitor this issue closely. Rated as a **CLASS II** defect.

Database: nucorja9.rbm Station: Roll Mill Rolls

MEASUR		POINT		OVERAL	L LEVEL	HFD	/ VHFD	
STD1A		- Stand	1A			(26-Nov-24)	
				OVERA	LL LEVEL	1K-20	KHz	
	мон			.023	In/Sec	.013	G-s	
	MIH			.088	In/Sec	.015		
	MIA			.084	In/Sec	.172		
	СОН			.115	In/Sec In/Sec	.037	G-s	
	GIA					.114		
	GIH					1.077		
	GI2			.153	In/Sec	.154	G-s	
	GI3					.880		
	GI4					.135		
	GI5			.065	In/Sec	.104	G-s	
	GI6			059	In/Sec	.044	G-s	
	GOH					.100		
STD2A		- Stand	2A			(26-Nov-24)	
				OVERA	LL LEVEL	1K-20	KHz	
	MOH			.128	In/Sec	.018 .044	G-s	
	MIH			.116	In/Sec	.044	G-s	
	MIA			.202	In/Sec	. 092	G-s	
	СОН			.239	In/Sec	.031	G-s	
STD1		- Stand	1			(26-Nov-24	•	
				OVERA	LL LEVEL	1K-20	KHz	
	MOH			.117	In/Sec	.030 .046	G-s	
	MIH							
	MIA			.564	In/Sec	. 357	G-s	
	GIA			.041	In/Sec	.032	G-s	
	GIH			.056	In/Sec	.023		
	СОН			.098	In/Sec	.088	G-s	
STD2		- Stand				(26-Nov-24		
						1K-20		
	MOH			.114	In/Sec	.088		
	MIH			.165	In/Sec In/Sec	.086		
	MIA							
	GIA			.147	In/Sec	.221		
	GIH			.120	In/Sec	.205	G-s	
	СОН			. 525	In/Sec	.097	G-s	
STD3		- Stand	3			(26-Nov-24		
					LL LEVEL			
	MOH				In/Sec			
	MIH				In/Sec			
	MIA				In/Sec			
	GIA					.0078		
	GIH				In/Sec			
	СОН			.185	In/Sec	.058	G-s	
STD4		- Stand	Stand 4		(26-Nov-24)			
					LL LEVEL			
	MOH				In/Sec			
	MIH				In/Sec			
	MIA					.096		
	GIA				In/Sec			
	GIH				In/Sec			
	СОН			.288	In/Sec	.018	G-s	
STD5		- Stand	5			(26-Nov-24)	
-		-		OVERA	LL LEVEL	1K-20		
	MOH					.111		
					,			

	MIH MIA GIA GIH GOH COH		.044 In/Sec .089 In/Sec .222 In/Sec .087 In/Sec .278 In/Sec .343 In/Sec	.213 G-s .136 G-s .132 G-s .030 G-s .432 G-s .064 G-s
STD6	- Stand MOH MIH GIA GIH GOH COH	6	(26 OVERALL LEVEL .105 In/Sec .049 In/Sec .142 In/Sec .115 In/Sec .055 In/Sec .248 In/Sec .271 In/Sec	-Nov-24) 1K-20KHz .015 G-s .076 G-s .051 G-s .026 G-s .097 G-s .639 G-s .256 G-s
STD7	- Stand MOH MIH GIA GIH GOH COH	7	(26 OVERALL LEVEL .044 In/Sec .046 In/Sec .094 In/Sec .059 In/Sec .385 In/Sec .506 In/Sec	-Nov-24) 1K-20KHz .050 G-s .087 G-s .077 G-s .040 G-s .184 G-s .473 G-s .096 G-s
STD8	- Stand MOH MIH GIA GIH COH	8	(26 OVERALL LEVEL .045 In/Sec .061 In/Sec .056 In/Sec .045 In/Sec .130 In/Sec	-Nov-24) 1K-20KHz .037 G-s .043 G-s .193 G-s .129 G-s .023 G-s .079 G-s
STD9	- Stand MOH MIH GIA GIH COH	9	(26 OVERALL LEVEL .087 In/Sec .081 In/Sec .136 In/Sec .110 In/Sec .107 In/Sec	-Nov-24) 1K-20KHz .041 G-s .153 G-s .073 G-s .097 G-s .024 G-s .042 G-s
STD11	- Stand MOH MIH GIA GIH GOH COH	11		.445 G-s .208 G-s .020 G-s
STD13	- Stand MOH MIH GIA GIH GOH COH	13	(26 OVERALL LEVEL .053 In/Sec .132 In/Sec .038 In/Sec .032 In/Sec .033 In/Sec .105 In/Sec	.063 G-s .085 G-s .133 G-s .126 G-s
STD15	- Stand MOH MIH MIA	15	OVERALL LEVEL .063 In/Sec	

GIA		.072 In/Sec	.172 G-s
GIH		.055 In/Sec .067 In/Sec	.115 G-s
СОН		.067 In/Sec	.083 G-s
STD16	- Stand 16	(26	
		OVERALL LEVEL	
MOH		.127 In/Sec	
MIH		.199 In/Sec	.023 G-s
MIA		.081 In/Sec	.059 G-s
GIA		.225 In/Sec	
GIH		.080 In/Sec	.024 G-s
GOH		.026 In/Sec 1.131 In/Sec	.021 G-s
СОН		1.131 In/Sec	.084 G-s
SOUTH AC	- SOUTH AIR COMPL	RESSOR QUINCY (26	
		OVERALL LEVEL	
MOH		.087 In/Sec	.241 G-s
MIH		.106 In/Sec	.186 G-s
MIA		.240 In/Sec	.215 G-s
		OVERALL LEVEL	
CIA		.254 In/Sec	
CIH		.137 In/Sec	.543 G-s
_			
D	atabase: nucorja tation: Roll Mi	9.rbm	
S	tation: Roll Mil	ll Utilities	
MEASUREMEN	T POINT	OVERALL LEVEL	
HYDPMP2	- Hydraulic Pump	Center (25	-Nov-24)
		OVERALL LEVEL .080 In/Sec	1K-20KHz
MOH			
MIH		.235 In/Sec	
PIV		.305 In/Sec	1.575 G-s
-			
HYDPMP3	- Hydraulic Pump	West (25	-Nov-24)
		OVERALL LEVEL	1K-20KHz
MOH		.116 In/Sec	.469 G-s
MIH		.371 In/Sec	
PIV		.258 In/Sec	1.489 G-s
	D]	(0)	
DESFAN	- Desolution Fan	•	5-Nov-24)
		OVERALL LEVEL	
MOH		.027 In/Sec	.057 G-s
MIH		.031 In/Sec .046 In/Sec	.034 G-s
MIA		.046 In/Sec	.0064 G-s
CONTRAIN	Combustion Dia		. No 04)
COMPAN	- Combustion Air	Fan (25 OVERALL LEVEL	5-Nov-24)
мон		.112 In/Sec	
		.112 IN/Sec	.117 G-S .145 G-S
MIH MIA		.108 In/Sec .080 In/Sec	.145 G-S .096 G-S
FIH		.080 IN/Sec	.187 G-s
FOH		.071 In/Sec .097 In/Sec	.187 G-s .412 G-s
FOR		.09/ 11/Sec	.412 G-S
FICEN	- Ejector Air Far		5-Nov-24)
LUCFAN	- Ejector Air Far	OVERALL LEVEL	1K-20KHz
мон		.030 In/Sec	.174 G-s
		.030 In/Sec	
MIH			
MIA		.018 In/Sec .018 In/Sec	
FIA		•	.068 G-s
FIH		.016 In/Sec	.128 G-s
FOH		.158 In/Sec	.363 G-S
001 01-00			
COLPMP2	- Furnace Cooling	g Pump center (25	
		OVERALL LEVEL	
MOH		.200 In/Sec	.321 G-s
мти		000 - /-	010 -
MIH		.220 In/Sec	.319 G-s
MIA		.220 In/Sec .102 In/Sec	

FCTSOUTH	- Furnace CT D	rive South (2	5-Nov-24)	
		OVERALL LEVEL		
МОН		.185 In/Sec	.060 G-s	
MIH		.144 In/Sec	.068 G-s	
MIA		.387 In/Sec	.043 G-s	
		• • • • •		
FCTNORTH		rive North (2		
		OVERALL LEVEL	1K-20KHz	
MOH		.583 In/Sec .309 In/Sec	.033 G-s	
MIH		.309 In/Sec	.051 G-s	
MIA		.187 In/Sec	.058 G-s	
SCLPMP2	- Scale Pit Pur	np North (2	(5-Nov-24)	
		OVERALL LEVEL	1K-20KHz	
MOH		.323 In/Sec	.280 G-s	
MIH		.157 In/Sec		
MIA		.127 In/Sec		
CTWTR1	- CT Pump East	/Middle Pump (2	5-Nov-24)	
		OVERALL LEVEL	1K-20KHz	
MOH		.067 In/Sec		
MIH		.046 In/Sec	.0041 G-s	
MIA		.036 In/Sec	.0032 G-s	
MILWTR2	- Mill Water Pu	ump Center (2	(5-Nov-24)	
		OVERALL LEVEL		
МОН		.040 In/Sec	.222 G-s	
MIH		.058 in/Sec	.513 G-S	
MIA		.042 In/Sec	.833 G-s	
	Mill Mater D	To a h	E No. 04)	
MILWIRI	- MIII Water Pt	mp East (2	14 2044-	
MOIT		OVERALL LEVEL .064 In/Sec		
MOH		.064 In/Sec .040 In/Sec	.490 G-s	
MIH				
MIA		.042 In/Sec	.167 G-s	
	OI VIBration Un			
Clarification	NO			
Acc	-> G-s RMS -> In/Sec PK			