LR Field Services

Prepared for Town of Damascus (12796)

86 North Road Damascus AR 72039

Table of Contents



Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.



Hi-Speed Industrial Service 7030 Ryburn Dr Millington, Tn 38053 901-873-5300

> FolderID: 103481 FormID: 21581465

Field Service Ticket

Town of Damascus (12796) 86 North Road Damascus, AR 72039

| Job Information | | |
|-----------------|---------------------|-------------------|
| 1. | Hi-Speed Job Number | 103481 |
| 2. | Asset Type | Water tower pumps |
| 3. | Make | Grundfos |
| 4. | Model | |



- 5. Serial Number
- 6. Customer Asset ID/Asset Name

Pump one and pump two.

Service Call Details

7. Service Objectives

To replace check valve and both motor/pump combos.

8. Services Performed

Replaced check valve, Grundfos pumps and motors. Set seals and test ran. Both pumps pump 160 gpm and pump two is at 16 amps at full speed. Customer was excited over the new units. We had a couple electrical and control issues but got them fixed.

















Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

1-7/1 2-8/2 3-9/red wire 4-5-6 connected together







9. Service Technician Recommendations

Approval Signatures

10. Service Technician Signature

Trevor Hall

11. Customer Signature

Randy Nicholson