



USG Interiors Gresing Survey

Machine Name	Point Name	Date	Before Db	Greased	After Db	Change +/-	Sealed	Notes
Effluent #1	ODE	9/30/2024	35.1	Y	32.4	-2.7	N	
Effluent #1	DE	9/30/2024	43.7	Y	42	-1.7	N	
Effluent #2	ODE	9/30/2024	58.1	Y	48.4	-9.7	N	
Effluent #2	DE	9/30/2024	63.1	Y	64.2	1.1	N	
Beater Agitator	ODE	9/30/2024	36.1	Y	31.4	-4.7	N	
Beater Agitator	DE	9/30/2024	51.9	Y	49.3	-2.6	N	
#3 Mix Tank Discharge Pump	ODE	9/30/2024	28.8	Y	22.6	-6.2	N	
#3 Mix Tank Discharge Pump	DE	9/30/2024	60.6	Y	36.2	-24.4	N	
Refiner #1	ODE	9/30/2024	N/A	N	N/A	0	N	The Out Board Bearing Grease Fitting Was Not Accessable Due To Fan Shroud
Refiner #1	DE	9/30/2024	31.4	Y	21.5	-9.9	N	
Refiner #2	ODE	9/30/2024	21.3	Y	20.3	-1	N	
Refiner #2	DE	9/30/2024	33.4	Y	28.2	-5.2	N	
Wet Jet Pump	ODE	9/30/2024	38.8	Y	37.4	-1.4	N	
Wet Jet Pump	DE	9/30/2024	46.2	Y	43.9	-2.3	N	
F/G Dust Collector	ODE	9/30/2024	40.6	Y	37	-3.6	N	
F/G Dust Collector	DE	9/30/2024	70	Y	66.6	-3.4	N	
#5 Expander	ODE	9/30/2024	69.7	Y	56.2	-13.5	N	
#5 Expander	DE	9/30/2024	60.2	Y	54.7	-5.5	N	
#6 Expander Dust Collector	ODE	9/30/2024	41.8	Y	37.8	-4	N	
#6 Expander Dust Collector	DE	9/30/2024	61.6	Y	57.5	-4.1	N	
#7 Expander Dust Collector	ODE	9/30/2024	43.2	Y	41.1	-2.1	N	
#7 Expander Dust Collector	DE	9/30/2024	61.6	Y	54.7	-6.9	N	
#8 Expander Dust Collector	ODE	9/30/2024	30.4	Y	29.6	-0.8	N	
#8 Expander Dust Collector	DE	9/30/2024	48.9	Y	44.5	-4.4	N	
Hydrapulper	ODE	9/30/2024	N/A	N	N/A	0	N	Bearings Has No Grease Fittings
Hydrapulper	DE	9/30/2024	N/A	N	N/A	0	N	Bearings Has No Grease Fittings
#1 White Water Loop Pump	ODE	9/30/2024	41.2	Y	35.2	-6	N	
#1 White Water Loop Pump	DE	9/30/2024	57.2	Y	50.7	-6.5	N	
Spare White Water Loop Pump	ODE	9/30/2024	37.5	Y	36.9	-0.6	N	
Spare White Water Loop Pump	DE	9/30/2024	57.9	Y	45.2	-12.7	N	
#1 Vacuum Pump	ODE	9/30/2024	36.8	Y	36.8	0	N	
#1 Vacuum Pump	DE	9/30/2024	42.5	Y	37.9	-4.6	N	
#2 Vacuum Pump	ODE	9/30/2024	36	Y	34.1	-1.9	N	
#2 Vacuum Pump	DE	9/30/2024	34.7	Y	33.4	-1.3	N	
#3 Vacuum Pump	ODE	9/30/2024	37.1	Y	35.4	-1.7	N	
#3 Vacuum Pump	DE	9/30/2024	49.3	Y	47.6	-1.7	N	
#3 Low Vacuum Pump	ODE	9/30/2024	37.8	Y	37.7	-0.1	N	
#3 Low Vacuum Pump	DE	9/30/2024	45.5	Y	37.7	-7.8	N	
Wet Zone Circulating Fan	ODE	9/30/2024	20.7	Y	20.3	-0.4	N	

Wet Zone Circulating Fan	DE	9/30/2024	30.3	Y	21.4	-8.9	N	
Dry Zone Circulatin Fan	ODE	9/30/2024	20.5	Y	19.8	-0.7	N	
Dry Zone Circulatin Fan	DE	9/30/2024	21.5	Y	17.4	-4.1	N	
Wet Zone Combustion Fan	ODE	9/30/2024	40.2	Y	35.5	-4.7	N	
Wet Zone Combustion Fan	DE	9/30/2024	53.1	Y	51.5	-1.6	N	
Dry Zone Combustion Fan	ODE	9/30/2024	36.6	Y	35.4	-1.2	N	
Dry Zone Combustion Fan	DE	9/30/2024	34.1	Y	27.9	-6.2	N	
Exhaust Fan	ODE	9/30/2024	38.6	Y	36.2	-2.4	N	
Exhaust Fan	DE	9/30/2024	42.7	Y	42.1	-0.6	N	
#1 Dust Collector	ODE	9/30/2024	51	Y	37.9	-13.1	N	
#1 Dust Collector	DE	9/30/2024	63.1	Y	62.2	-0.9	N	
#2 Dust Collector	ODE	9/30/2024	47.4	Y	47.2	-0.2	N	
#2 Dust Collector	DE	9/30/2024	61.1	Y	60.4	-0.7	N	
#3 Dust Collector	ODE	9/30/2024	N/A	N	N/A	0	N	No Grease Fitting
#3 Dust Collector	DE	9/30/2024	63.6	Y	62.8	-0.8	N	