

Field Service Ticket

Modern Build (12793) 315 Dupree Drive Jacksonville, AR 72076 Hi-Speed Industrial Service 7030 Ryburn Dr Millington, Tn 38053 901-873-5300

> FolderID: 103636 FormID: 23480469

Job Information			
1.	Hi-Speed Job Number	103636	
2.	Asset Type	dust collector fan	
3.	Make	dust collector	
4.	Model		
5.	Serial Number		
6.	Customer Asset ID/Asset Name	dust collector	
Servic	Service Call Details		

ervice Call Details

7. Service Objectives

To check the voltage going to the dust collector fan

8. Services Performed P8

Volts are 250, 255 and 249. Line to ground is 124, 125 and 220. Contactor is working properly.











9. Service Technician Recommendations

Approval Signatures

10. Service Technician Signature Trevor Hall



Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.



Jesse Harryman

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.