



Hi-Speed Industrial Service  
7030 Ryburn Dr  
Millington, Tn 38053  
901-873-5300

## Field Service Ticket

FolderID: 104236  
FormID: 23719476

**Kimberly Clark (10176-KCM)**  
500 Murphy Dr.  
Maumelle, AR 72113

### Job Information



- |                        |        |    |
|------------------------|--------|----|
| 1. Hi-Speed Job Number | 104236 |    |
| 2. Asset Type          | fan    | P2 |



- |         |  |    |
|---------|--|----|
| 3. Make |  | P3 |
|---------|--|----|



- |          |  |    |
|----------|--|----|
| 4. Model |  | P4 |
|----------|--|----|



- |                  |  |    |
|------------------|--|----|
| 5. Serial Number |  | P5 |
|------------------|--|----|



Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.



Service Call Details



7. Service Objectives

Balance fan at 55% and then check at 95%



Final reading at 95%

8. Services Performed

At 55% initial reading .7 mils fan end and .001 motor end. Final reading fan end 0.03 mill and 0.001 motor end. Reading at 95% fan end 0.3 mils and 0.01 mils motor end.



Final reading at 55%

9. Service Technician Recommendations

Initial reading before balance correction



Approval Signatures

10. Service Technician Signature

Shon Jones



11. Customer Signature

**Daniel Borling**

