

7030 Ryburn Dr. Millington, TN

Phone: (901) 873-5300

Fax: (901) 873-5301

www.gohispeed.com

March 4, 2025

NUCOR Melt Shop Subject: January 2025 vibration survey

Below is a summary report for the Melt Shop monthly vibration survey that was performed on 02/25/25. Most of the machines surveyed were found to be in good condition except for the following:

QualiTest® uses a four-step rating system for defects.

<u>Class I:</u> Defect is present, but effect on reliability is not clear; no immediate action is required. Continue to normally monitor.

**<u>Class II:</u>** Defect (s) present that may cause problem in long term (2-6 months). Repair during normal maintenance scheduling. Continue to monitor.

**<u>Class III</u>**: Defect (s) present that may cause failure in short term (less than 2 months). This should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.

**<u>Class IV</u>**; Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs

*Hi-Speed* Industrial Service tests and inspects industrial machinery and equipment and makes recommendations concerning maintenance and repairs based on its experience in the field of industrial repair and maintenance. The information contained herein is provided as an opinion only, not as a guaranty or warranty of the matters discussed herein.

As always, it has been a pleasure to serve NUCOR Steel Flowood-Jackson, MS. If there are any comments or questions, do not hesitate to contact us.

Sincerely,

1. Maruell

ISO Certified Vibration Analyst, Category III



Cell: 901-486-4565 Email: <u>kwilliam@gohispeed.com</u>

# Defects

#### Middle Caster Mold Water Pump

*Pump was down this survey; however, the following still applies:* Vibration data shows issues in the pump. Data suggests looseness/wear of the pump bearings/fits. Impeller and other pump internals may also have wear. The pump will likely need attention soon. Rated as a **CLASS II** defect.

### East Booster Pump

Motor vibration data indicates defects are present in the motor bearings. Inspect motor as scheduling allows. Rated as a **CLASS III** defect.

#### Middle Caster Spray Water Pump (2 from the left)

Top motor data shows non-synchronous peaks present that are indicative of bearing faults. Inspect motor bearing soon. Rated as a **CLASS II** defect.

#### Cooling Tower #4 Supply Pump

*Pump was down this survey; however, the following still applies:* Pump data shows some signs of bearing defects/wear in the ODE pump bearing. Inspect pump as scheduling allows. Rated as a **CLASS III** defect.

#### Cooling Tower #5 Supply Pump

Pump has some elevated 1 x rpm axial vibration. For now, it is recommended to inspect couplings, alignment, and all pump fasteners as scheduling allows. Rated as a **CLASS II** defect.

#### Cooling Tower #6 Supply Pump

The pump vibration data still indicates that there is bearing wear, and possibly cavitation in the pump. Inspect ODE pump bearing. Ensure the pump has no inlet restrictions and is operating in the correct part of the curve. Impeller may have excessive wear. Rated as a **CLASS II** defect.

## Spray Chamber Exhaust Fan

**Could not access fan this survey, however the following likely still applies:** Motor and fan both have high vibration again this survey. Belts could be slipping which is allowing the fan to operate at speeds near a resonance which causing high 1 x fan rpm vibration in the unit. High 1 x rpm vibration could also be structural issue and or fan imbalance. Inspect all motor base mounts/fasteners. Inspect fan for build-up and inspect belt tension soon. Rated as a **CLASS III** defect.

Database:	nucorja9.rbm		
Station:	Melt Shop		

MEASUREMENT POINT	OVERALL LEVEL	HFD / VHFD
WCMWP - WEST CASTER MOLL	OVERALL LEVEL	1K-20KH-
MOH	075 Tr/Sec	172 C-e
мтн	076 In/Sec	292 G-s
мта	070 In/Sec	294 G-s
DIA	333 In/Sec	258 G-s
PTH	136 In/Sec	535 G-s
POH	200 Tn/Sec	503 G-s
1011	.200 111, 500	.505 6 5
ECMWP - EAST CASTER MOLD	WATER PUMP (25-1	Feb-25)
	OVERALL LEVEL	1K-20KHz
MOH	.051 In/Sec	.279 G-s
MIH	.069 In/Sec	.445 G-s
MIA	.298 In/Sec	.371 G-s
PIA	.308 In/Sec	2.117 G-s
PIH	.158 In/Sec	1.910 G-s
POH	.178 In/Sec	1.905 G-s
POV	.181 In/Sec	1.446 G-s
PIV	.250 In/Sec	2.099 G-s
MIV	.427 In/Sec	.678 G-s
MOV	.065 In/Sec	.766 G-s
EBOSTRP - EAST Booster PUM	IP (25-1	Feb-25)
	OVERALL LEVEL	1K-20KHz
MOH	.081 In/Sec	.769 G-s
MIH	.145 In/Sec	2.102 G-s
MIA	.120 In/Sec	1.5/2 G-s
	.200 In/Sec	.154 G-s
PIH	.129 In/Sec	.1/1 G-s
POH	.081 In/Sec	.207 G-S
ECSWP 11FT - EAST CASTER SPRA	Y WP 1 LEFT (25-)	Feb-25)
	OVERALL LEVEL	1K-20KHz
МОН	.095 In/Sec	.200 G-s
MIH	.065 In/Sec	.282 G-s
MIA	.059 In/Sec	.180 G-s
MCSWP 2LFT - MID CASTER SPRAY	WP 2 LEFT (25-1	Feb-25)
	OVERALL LEVEL	1K-20KHz
MOH	.437 In/Sec	.621 G-s
MIH	.153 In/Sec	.832 G-s
MIA	.118 In/Sec	.466 G-s
MODER OF MED CODAY		Dab 05)
MCSWP 3RT - MID CASTER SPRAY	WP 3 RIGHT (25-)	1v 20vu-
MOU	240 TP/Sec	269 C c
MOH	.249 IN/Sec	.200 G-S
мта	134  Tr/Sec	.030 G-s
MIA	.154 11/560	.020 8 3
MSERVOHYDP - MIDDLE SERVO Hyd	L PUMP (25-1	Feb-25)
	OVERALL LEVEL	1K-20KHz
МОН	.219 In/Sec	.250 G-s
MIH	.082 In/Sec	.311 G-s
PIV	.218 In/Sec	.662 G-s
WSERVOHYDP - WEST SERVO Hyd F	PUMP (25-1	Feb-25)
	OVERALL LEVEL	1K-20KHz
MOH	.084 In/Sec	.278 G-s
MIH	.093 In/Sec	.200 G-s
PIV	.245 In/Sec	1.073 G-s

SERVOHRECP	-	SERVO Hyd RECIF	RC PUMP	(25-Feb-25)
			OVERALL LEVEL	1K-20KHz
MOH			.059 In/Sec	.158 G-s
MIH			.141 In/Sec	.589 G-s
PIV			.274 In/Sec	1.106 G-s
2DEKRECIP	-	2ND DECK L&S Hy	d RECIRC PUM	(25-Feb-25)
			OVERALL LEVEL	1K-20KHz
MOH			.142 In/Sec	.233 G-s
MIH			.120 In/Sec	.319 G-s
PIV			.239 In/Sec	1.552 G-s
M2DECKHYDP	-	MIDDLE 2ND DECH	K Hyd PUMP	(25-Feb-25)
			OVERALL LEVEL	1K-20KHz
MOH			.129 In/Sec	.080 G-s
MIH			.043 In/Sec	.153 G-s
PIV			1.318 In/Sec	.021 G-s
S2DECKHYDP	-	SOUTH 2ND DECK	Hyd PUMP	(25-Feb-25)
			OVERALL LEVEL	1K-20KHz
MOH			.098 In/Sec	.272 G-s
MIH			.088 In/Sec	.520 G-s
PIV			.504 In/Sec	2.064 G-s
<b>1SUPLYP</b>	-	#1 Supply Pump		(25-Feb-25)
			OVERALL LEVEL	1K-20KHz
MOH			.089 In/Sec	.234 G-s
MIH			.137 In/Sec	.152 G-s
MIA			.173 In/Sec	.119 G-s
PIA			.471 In/Sec	.686 G-s
PIH			.344 In/Sec	.915 G-s
POH			.229 In/Sec	.940 G-s
			,	
2SUPLYP	_	#2 Supply Pump		(25-Feb-25)
			OVERALL LEVEL	1K-20KHz
MOH			064 In/Sec	636 G-s
мтн			061 In/Sec	578 G-s
мта			068 In/Sec	296 6-5
DTA			214 In/Sec	323 6-6
DTH			233 In/Sec	533 C-e
			222 In/Sec	1 076 G-s
FOI			.222 111/560	1.070 8 3
3SUPLYP	_	#3 Supply Pump		(25-Feb-25)
5501211		"o odbbrl ramb	OVERALL LEVEL	1K-20KHz
MOH			066 Tn/Sec	840 G-s
мтн			072 In/Sec	901 G-s
мта			076 In/Sec	705 G-s
DTA			202 In/Sec	372 G-s
DTH			173 In/Sec	475 G-s
POH			206 In/Sec	919 G-s
1011			.200 111, 566	.919 0 5
5SUPLYP	_	#5 Supply Pump		(25-Feb-25)
0001211		"o ouppij rump	OVERALL LEVEL	1K-20KHz
мон			.051 Tn/Sec	.604 G-9
мтш			053 Tr/Sec	602 6-5
мтъ			003  Tr/Sec	302 0-5
MIA			202 To/Coc	.323 G-8 213 C-4
FIA DTT			120 To/Coo	.243 G-8 637 C
PIR			254 To/Sec	1 220 C
POH			.234 IN/Sec	1.329 G-S
6SUPLYP	_	#6 Supply Pump		(25-Feb-25)
JUCITI	-	"o pubbry rump	OVERAT.T. T.EVET	1K-20KH-
MOP			075 Tr/sec	271 6-6
MTH			075 Tp/Sec	102 C-2
MIH			080 To/Sec	1/2 C
MIA DTA			132 To/Coo	.142 G-S
PIA			162 Tm/SeC	.209 G-S
PIH			.ioz in/SeC	.230 G-S
ייסס			186 70/000	1 000 0

CBRA	- CASTER BAGHOUSE	REVERSE AIR	(25-Feb-25)	
		OVERALL LEVEL	1K-20KHz	
MOH		.054 In/Sec	.159 G-s	
MIH		.062 In/Sec	.159 G-s	
MIA		.062 In/Sec	.151 G-s	
FIH		.026 In/Sec	.249 G-s	
FOH		.058 In/Sec	.078 G-s	
CBID	- CASTER BAGHOUSE	ID FAN	(25-Feb-25)	
-		OVERALL LEVEL	1K-20KHz	
MOH		.039 In/Sec	.085 G-s	
MOV		.020 In/Sec	.100 G-s	
MIH		.034 In/Sec	.091 G-s	
MIV		.033 In/Sec	.168 G-s	
MIA		.020 In/Sec	.197 G-s	
FIA		.042 In/Sec	.523 G-s	
FIH		.058 In/Sec	.728 G-s	
FIV		.040 In/Sec	.549 G-s	
FOH		.067 In/Sec	.682 G-s	
FOV		.028 In/Sec	.690 G-s	
FOA		.076 In/Sec	.439 G-s	
FRAF	- Furnace REVERSE	AIR Fan	(25-Feb-25)	
		OVERALL LEVEL	1K-20KHz	
MOH		.044 In/Sec	.245 G-s	
MIH		.052 In/Sec	.564 G-s	
MIA		.033 In/Sec	.301 G-s	
FIA		.118 In/Sec	.421 G-s	
FIH		.047 In/Sec	.418 G-s	
FOH		.040 In/Sec	.407 G-s	
EFBHF	- East Furnace Bac	n House Fan	(25-Feb-25)	
		OVERALL LEVEL	1K-20KHz	
MOH		.075 In/Sec	.667 G-s	
MIH		.081 In/Sec	.524 G-s	
MIA		.035 In/Sec	.465 G-s	
FIA		.084 In/Sec	.955 G-s	
FIH		.126 In/Sec	.896 G-s	
FOH		.105 In/Sec	.997 G-s	
WFBHF	- WEST Furnace Bac	n House Fan	(25-Feb-25)	
		OVERALL LEVEL	1K-20KHz	
МОН		.084 In/Sec	.286 G-s	
MIH		.103 In/Sec	.206 G-s	
MIA		.050 In/Sec	.560 G-s	
FIA		.096 In/Sec	1.028 G-s	
FIH		.127 In/Sec	.469 G-s	
FOH		.091 In/Sec	1.008 G-s	
Clarification	Of Vibration Units	3:		
Acc	-> G-s RMS			
Vel	-> In/Sec PK			