

AC Recondition Repair Report

FolderID: 99373 FormID: 12802965

7030 Ryburn Dr Millington, Tn 38053 901-873-5300

Hi-Speed Industrial Service

Peco Foods

625 S. Allen Street Batesville, AR 72501

Priorities Found: 1 - High

9 - Good

| Genera | al | | |
|--------|------------------------|-----------------------|--|
| 1. | Job Number | 99373 | |
| 2. | Report Date | 02/10/2022 | |
| 3. | Customer | PECO Foods Batesville | |
| Name | Name Plate Information | | |

US Motors P5 Manufacturer


































| 5. | Model | UJ15P2DM FK49 | |
|-----|---------------|--------------------------|--|
| 6. | Serial Number | Z 08 7699473-0025 M 0002 | |
| 7. | Horsepower | 15 | |
| 8. | KW | | |
| 9. | Volts | 460 Volts | |
| 10. | Amps | 18.4 | |
| 11. | RPM | 1775 | |
| 12. | Frame | 254JM | |
| 13. | Enclosure | TEFC | |
| 14. | Cycles | 60 | |
| 15. | Phase | 3 | |

| 16. | Service Factor | 1.25 |
|-------------|--------------------------------|----------|
| 17. | Motor Mount Position | |
| Initial I | nspection | Ō |
| 18. | Number of Leads | 12 |
| 19. | Lead Length | 8 Inches |
| 20. | Lead Size | |
| 2 1. | Lead Condition | (P) Pass |
| 22. | Lead Markings | 1-12 |
| 23. | Lug Size, Condition, and Type | |
| 24. | Winding RTD's | |
| 25. | Winding Rtd's Condition | |
| 26. | Shaft Run Out | |
| 27. | Does Shaft Turn Freely | no |
| 28. | Does Shaft Have Visible Damage | |
| 29. | Bearing Rtd's | |
| 30. | Bearing Rtd's Condition | |
| 31. | Contamination | |
| | Water | |
| 32. | Frame Condition | P106 |



33. Fan Condition (P) Pass P109





34. Broken or missing components

Initial Electric Test

0

35. Resistance to Ground







| 55. | Bearing ODE Type | regular ball bearing | |
|-----|--------------------|----------------------|-----|
| 56. | ODE Bearing Qty. | 1 | |
| 57. | Insulated Bearing | no | |
| 58. | Lubrication Type | grease | |
| 59. | Grease Condition | (F) Fail | |
| - | Water contaminated | | |
| 60. | Bearing Retainers | (Y) Yes | P80 |



| 61. | Shaft Grounding Device | (NA) Not Applicable | |
|-----|------------------------|---------------------|-----|
| 62. | DE Seal | (Y) Yes | |
| 63. | DE Seal Type/Size | dust seal worn | P90 |



| 64. | ODE Seal | |
|--------|--------------------|-------------------|
| 65. | ODE Seal Type/Size | |
| Root C | Cause of Failure | |
| 66. | Component Failure | seal/impeller |
| 67. | Cause of Failure | |
| | Worn | |
| 68. | Comments | |
| 69. | Service Technician | Terrence. Holland |
| | \mathcal{A} | 4.11 |

| Mach | ine Fit Inspection Report | |
|------|--|----------|
| 70 | . Shaft Run Out | |
| 71 | . Initial Shaft Run Out | " |
| 72 | . Final Shaft Run Out | |
| 73 | . DE Bearing Shaft Fit | (P) Pass |
| 74 | . DE Initial Shaft Bearing Fit Size 1 | 1.969 " |
| 75 | . DE Initial Shaft Bearing Fit Size 2 | 1.9691 " |
| 76 | . DE Initial Shaft Bearing Fit Size 3 | 1.9691 " |
| 77 | . DE Finial Shaft Bearing Fit Size 1 | |
| 78 | . DE Finial Shaft Bearing Fit Size 2 | |
| 79 | . DE Finial Shaft Bearing Fit Size 3 | |
| 80 | . ODE Bearing Shaft Fit | (P) Pass |
| 81 | . ODE Initial Shaft Bearing Fit Size 1 | п |
| 82 | . ODE Initial Shaft Bearing Fit Size 2 | |
| 83 | . ODE Initial Shaft Bearing Fit Size 3 | |
| 84 | . ODE Finial Shaft Bearing Fit Size 1 | |
| 85 | . ODE Finial Shaft Bearing Fit Size 2 | |
| 86 | . ODE Finial Shaft Bearing Fit Size 3 | |
| 87 | . DE Air Seal Shaft Fit | |
| 88 | . DE Initial Air Seal Shaft Size | |
| 89 | . DE Final Air Seal Shaft Size | |
| 90 | ODE Air Seal Shaft Fit | |
| 91 | ODE Initial Air Seal Shaft Size | |
| 92 | ODE Final Air Seal Shaft Size | |
| 93 | . DE Endbell Fit | |
| 94 | . DE Initial Endbell Fit Size 1 | |
| 95 | . DE Initial Endbell Fit Size 2 | |
| 96 | . DE Initial Endbell Fit Size 3 | |
| 97 | . DE Final Endbell Fit Size 1 | |
| 98 | . DE Finial Endbell Fit Size 2 | |
| 99 | . DE Final Endbell Fit Size 3 | |
| 100 |). DE Endbell Fit Insulated | |
| 101 | . DE Endbell Air Seal Fit | |
| 102 | 2. Initial Endbell Air Seal Fit Size | |
| 103 | 3. Finial Endbell Air Seal Fit Size | |

| | ODE Endbell Fit |
|--------|-----------------------------------|
| | ODE Initial Endbell Fit Size 1 |
| | ODE Initial Endbell Fit Size 2 |
| | ODE Initial Endbell Fit Size 3 |
| | ODE Final Endbell Fit Size 1 |
| | ODE Final Endbell Fit Size 2 |
| | ODE Final Endbell Fit Size 3 |
| | ODE Endbell Fit Insulated |
| | ODE Endbell Air Seal Fit |
| | ODE Initial Endbell Seal Fit Size |
| | ODE Finial Endbell Seal Fit Size |
| | Foot Flatness |
| | Foot Condition |
| | Flange Condition |
| 118. | Service Technician |
| Balanc | ing Report |
| 119. | Balance Type |
| 120. | Balance Operating Speed |
| 121. | Start Left End |
| 122. | Start Right End |
| 123. | Balancing Specification |
| 124. | Finish Left End |
| 125. | Finish Right End |
| 126. | Service Technician |
| Assem | bly and Final Test |
| 127. | Meggar Testing Reading |
| 128. | Surge Test |
| 129. | Hi-Pot |
| 130. | Winding Resistance 1-2 |
| 131. | Winding Resistance 2-3 |
| 132. | Winding Resistance 1-3 |
| 133. | Test Run Voltage Phase A |
| 134. | Test Run Amps A |
| 135. | Test Run Voltage Phase B |
| 136. | Test Run Amps B |
| 137. | Test Run Voltage Phase C |
| | Test Run Amps C |
| 139. | DE Horizontal Vibration Reading |
| 140. | DE Vertical Vibration Reading |
| 141. | DE Axial Vibration Reading |
| | ODE Horizontal Vibration Reading |
| | ODE Vertical Vibration Reading |
| | ODE Axial Vibration Reading |
| 145. | Ambient Temp at start of Test Run |
| 146. | Temp at 5 minutes |
| 147. | Temp at 10 minutes |
| 148. | Temp at 15 minutes |
| | |
| 149. | Temp at 20 minutes |

| 150. | Temp at 25 minutes |
|------|--------------------|
| 151. | Temp at 30 minutes |
| 152. | Temp at 35 minutes |
| 153. | Temp at 40 minutes |
| 154. | Temp at 45 minutes |
| 155. | Temp at 50 minutes |
| 156. | Temp at 55 minutes |
| 157. | Temp at 60 minutes |
| 158. | Motor Paint |
| 159. | Service Technician |