

Job Information

Job #: 135664 Date: January 17,

2018

Priority: 2 Authorized OT: No Authorized by: Terry

Customer Information

Name: KTG Motor#:

Name Plate Information

Manufacturer: GE Enclosure: Totally Enclosed Horsepower/kW: 100

Fan Cooled

Serial#: N8127018 Model#: 5k1504fg9 Service Factor:

Frame: 504u Rated RPM: 1770 Rated Voltage: 460

Phase: Rated Amps: 241/120 Cycles:

Special design: No



AC Electrical Inspection

Megs at reassembly:	Good	Surge at reassembly:	Good	Hi-pot reassembly:	Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing

Test	Run	Insp	ecti	on
			,	•

Date

— I have merged this motor and verified that all electrical tests are complete!

Power Supply

Phase A Phase B Phase C

No Load Voltage

No Load Current

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



Test Run Inspection (Continued)

Ambient Temp: 60

TIME DE Degree Change ODE Degree Change

START: 60 1 61

5 MIN: 61 1 62

10 MIN: 64 1 65

15 MIN: 66 1 65

20 MIN:

25 MIN:

30 MIN:

35 MIN:

40 MIN:

45 MIN:

50 MIN:

55 MIN:

60 MIN:



Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE 0.067 0.072 0.035

ODE 0.069 0.064 0.042

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos







Yes, the shaft has been isolated for delivery.

Service Tech name: Terry Frazier

Service Tech signature: