

Job Information

Job #: 136549 Date: July 20, 2018

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: South Treatment Plant Motor#: 136549

Name Plate Information

Manufacturer: US MOTORS Enclosure: Open Drop Proof Horsepower/kW: 350hp

(ODP)

Serial#: Model#: G41644/21021100 Service Factor: 1.15

4T3R-3

Frame: 6808PA Rated RPM: 595 Rated Voltage: 4000

Phase: 3 Rated Amps: Cycles: 60

Special design: No

Date

July 20, 2018



AC Electrical Inspection

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing 0.893400 0.892400 0.893300 0.1

Test Run Inspection

— I have merged this motor and verified that all electrical tests are complete!

Power Supply

,	Phase A	Phase B	Phase C
		2	
No Load Voltage	4000	4000	4000
No Load Current	319.1	333.1	323.0

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



Test Run Inspection (Continued)

Ambient Temp: 89

TIME DE Degree Change ODE Degree Change
START: 89 0 89 0

5 MIN: 90 1 91 2

10 MIN: 92 2 92 1

15 MIN: 94 2 93 1

20 MIN:

25 MIN:

30 MIN:

35 MIN:

40 MIN:

45 MIN:

50 MIN:

55 MIN:

60 MIN:



DE

ODE

Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal	VDE	Axial
0.084	0.054	0.036
0.65	0.036	0.023

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos







Yes, the shaft has been isolated for delivery.

Service Tech name: Michael Jordan

Service Tech signature: