

Job Information

Job #: 136563 Date: April 6, 2018

Priority: 2 Authorized OT: No Authorized by:

Customer Information

Name: CS3 Motor#:

Name Plate Information

Manufacturer: York Enclosure: Open Drop Proof Horsepower/kW: 286

(ODP)

Serial#: 20009867-ID Model#: 024-26513-468 Service Factor: 1.10

Frame: 447 TDZ Rated RPM: 3600 Rated Voltage: 460

Phase: 3 Rated Amps: 310 Cycles: 60

Special design: No



AC Electrical Inspection

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing 0.016739 0.016917 0.017231 2.9

Test Run Inspection

Date April 6, 2018

Yes I have merged this motor and verified that all electrical tests are complete!

Power Supply

Phase A Phase B Phase C

No Load Voltage 460 464 462

No Load Current 57.47 66.43 72.07

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



Test Run Inspection (Continued)

Ambient Temp: 65

TIME Degree Change ODE Degree Change DE START: 65 0 65 0 5 MIN: 72 7 71 6 9 10 MIN: 80 15 74 15 MIN: 82 17 75 10

20 MIN:

25 MIN:

30 MIN:

35 MIN:

40 MIN:

45 MIN:

50 MIN:

55 MIN:

60 MIN:



Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE 0.024 0.037 0.038

ODE 0.024 0.026 0.038

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos







Yes, the shaft has been isolated for delivery.

Service Tech name: Marc Pilgrim

Service Tech signature:

Mar PS