

#### **Job Information**

Job #: 136631 Date: January 22,

2019

Priority: — Authorized OT: No Authorized by:

**Customer Information** 

Name: P&P Motor#: 136631

**Name Plate Information** 

Manufacturer: Reliance Enclosure: Open Drop Proof Horsepower/kW: 200

(ODP)

Serial#: B391180-010. Model#: Service Factor: 1.25

L002GL

Frame: 445TSD Rated RPM: 3570 Rated Voltage: 460

Phase: 3 Rated Amps: 227 Cycles: 60

Special design: Yes



### **AC Electrical Inspection**

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing

### **Test Run Inspection**

Date January 22, 2019

Yes I have merged this motor and verified that all electrical tests are complete!

**Power Supply** 

 Phase A
 Phase B
 Phase C

 No Load Voltage
 460.3
 460.1
 460.0

 No Load Current
 54.84
 56.19
 54.30

**Temperatures: (Degrees Fahrenheit)** 

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



# **Test Run Inspection (Continued)**

Ambient Temp: 60.3

TIME	DE	Degree Change	ODE	Degree Change
START:	60	0	60	0
5 MIN:	62	2	62	2
10 MIN:	64	2	62	0
15 MIN:	66	2	63	1

20 MIN:

25 MIN:

30 MIN:

35 MIN:

40 MIN:

45 MIN:

50 MIN:

55 MIN:

60 MIN:



## **Test Run Inspection (Continued)**

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE 0.029 0.029 0.032

ODE 0.035 0.035 0.026

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

### **Additional photos**







Yes, the shaft has been isolated for delivery.

Service Tech name: Michael Jordan

Service Tech signature: