

Job Information

Job #: 137916 Date: December 10,

2018

Priority: — Authorized OT: No Authorized by: Terry f

Customer Information

Name: Usg Motor#:

Name Plate Information

Manufacturer: Siemens Enclosure: Open Drop Proof Horsepower/kW: 250

(ODP)

Serial#: Model#: 1la4494se1 Service Factor:

Frame: Rated RPM: 1785 Rated Voltage: 460

Phase: Rated Amps: 281 Cycles:

Special design: No

Date

December 10, 2018



AC Electrical Inspection

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing 0.2 0.2 0.2 0.2

Test Run Inspection

I have merged this motor and verified that all electrical tests are complete!

Power Supply

	Phase A	Phase B	Phase C
No Load Voltage	460	461	462
No Load Current	80	81	80

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



Test Run Inspection (Continued)

Ambient Temp:				
TIME	DE	Degree Change	ODE	Degree Change
START:				
5 MIN:				
10 MIN:				
15 MIN:				
20 MIN:				
25 MIN:				
30 MIN:				
35 MIN:				
40 MIN:				
45 MIN:				
50 MIN:				
55 MIN:				
60 MIN:				



DE

ODE

Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal	VDE	Axial
0.054	0.043	0.032
0.062	0.054	0.030

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos







Yes, the shaft has been isolated for delivery.

Service Tech name: Terry

Service Tech signature:

