

#### **Job Information**

Job #: 138133 Date: February 26,

2019

Priority: — Authorized OT: No Authorized by:

**Customer Information** 

Name: KTG Motor#: 138133

**Name Plate Information** 

Manufacturer: ABB Enclosure: Totally Enclosed Horsepower/kW: 683

Fan Cooled

Serial#: M3BP400LB6B3 Service Factor: S1

Frame: 400LB Rated RPM: 1194 Rated Voltage: 480

Phase: 3 Rated Amps: 780 Cycles: 60

Special design: No



### **AC Electrical Inspection**

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

**Winding Resistance Incoming** 

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing

## **Test Run Inspection**

Date February 26, 2019

Yes I have merged this motor and verified that all electrical tests are complete!

**Power Supply** 

,	Phase A	Phase B	Phase C
No Load Voltage	480.2	481.3	481.0
No Load Current	330.1	331.1	331.0

**Temperatures: (Degrees Fahrenheit)** 

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



# **Test Run Inspection (Continued)**

Ambient Temp: 62

TIME	DE	Degree Change	ODE	Degree Change
START:	61	0	61	0
5 MIN:	72	11	66	5
10 MIN:	74	2	68	2
15 MIN:	76	2	70	2

20 MIN:

25 MIN:

30 MIN:

35 MIN:

40 MIN:

45 MIN:

50 MIN:

55 MIN:

60 MIN:



# **Test Run Inspection (Continued)**

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

DE 00.51 0.014 0.025

ODE 0.035 0.019 0.024

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

### **Additional photos**







Yes, the shaft has been isolated for delivery.

Service Tech name: Michael Jordan

Service Tech signature: