

Job Information

Job #: 139650 Date: May 10, 2019

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: MLGW Motor#:

Name Plate Information

Manufacturer: Westinghouse Enclosure: Open Drop Proof Horsepower/kW: 100

(ODP)

Serial#: 2 Model#: 17n6654 Service Factor:

Frame: 505P Rated RPM: 1175 Rated Voltage: 460

Phase: 3 Rated Amps: 118 Cycles:

Special design: Yes



AC Electrical Inspection

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing 0.0573 0.0576 0.0581

Test Run Inspection

Date May 10, 2019

Yes I have merged this motor and verified that all electrical tests are complete!

Power Supply

Phase A Phase B Phase C

No Load Voltage 460 460 460

No Load Current 27.9 30.9 31.8

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



Test Run Inspection (Continued)

Ambient Temp:				
TIME	DE	Degree Change	ODE	Degree Change
START:				
5 MIN:				
10 MIN:				
15 MIN:				
20 MIN:				
25 MIN:				
30 MIN:				
35 MIN:				
40 MIN:				
45 MIN:				
50 MIN:				
55 MIN:				
60 MIN:				



Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE 0.034 0.074 0.047

ODE 0.056 0.068

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos







Yes, the shaft has been isolated for delivery.

Service Tech name: Dan Mahan

Service Tech signature:



