

Job Information

Job #: 140148 Date: July 15, 2019

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: HSLR Motor#: 140148

Name Plate Information

Manufacturer: Reliance Enclosure: Open Drop Proof Horsepower/kW: 100

(ODP)

Serial#: F40G240M G3. Model#: 21MN400240 Service Factor: 1.15

SS

Frame: 405T Rated RPM: 1785 Rated Voltage: 460

Phase: 3 Rated Amps: 111 Cycles: 60

Special design: No



AC Electrical Inspection

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing

Test Run Inspection

Date July 15, 2019

— I have merged this motor and verified that all electrical tests are complete!

Power Supply

	Phase A	Phase B	Phase C
No Load Voltage	462	465	463
No Load Current	27	28	28

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



Test Run Inspection (Continued)

Ambient Temp: 78

TIME	DE	Degree Change	ODE	Degree Change
START:	78	0	78	0
5 MIN:	79	1	79	1
10 MIN:	79	0	80	1
15 MIN:	82	2	82	2

20 MIN:

25 MIN:

30 MIN:

35 MIN:

40 MIN:

45 MIN:

50 MIN:

55 MIN:

60 MIN:



Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE 0.037 0.040 0.030

ODE 0.036 0.043 0.028

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos







Yes, the shaft has been isolated for delivery.

Service Tech name: Michael Jordan

Service Tech signature:

MADON