

Job Information

Job #: 140435 Date: February 7, 2020

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: Nucor Motor#:

Name Plate Information

Manufacturer: P&H Enclosure: Totally Enclosed Horsepower/kW: 15

Non-Ventilated

Serial#: 509337-692 Model#: 281M 1020-E Service Factor:

Frame: 284 Rated RPM: 1145 Rated Voltage: 460

Phase: 3 Rated Amps: 20.3 Cycles: 60

Special design: No



AC Electrical Inspection

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing 0.892100 0.894100 0.897500 0.6

Test Run Inspection

Inspection Date February 7, 2020

Yes I have merged this motor and verified that all electrical tests are complete!

Power Supply

Phase A Phase B Phase C

No Load Voltage 459.2 460.4 459.9

No Load Current 7.5 7.7 7.8

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



Test Run Inspection (Continued)

Ambient Temp: 60

TIME DE Degree Change ODE Degree Change

START: 60 0 60 0

5 MIN: 61 1 62 2

10 MIN: 61 0 62 0

15 MIN:

20 MIN:

25 MIN:

30 MIN:

35 MIN:

40 MIN:

45 MIN:

50 MIN:

55 MIN:

60 MIN:



DE

ODE

Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal	VDE	Axial
0.036	0.032	0.036
0.035	0.034	0.041

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos







Yes, the shaft has been isolated for delivery.

Service Tech name: Shawn

Service Tech signature:

The Agent