

#### **Job Information**

Job #: 141212 Date: November 25,

2019

Priority: — Authorized OT: No Authorized by:

**Customer Information** 

Name: Lucy Wood Stock Terminal Motor#:

**Name Plate Information** 

Manufacturer: Reliance Enclosure: Totally Enclosed Horsepower/kW: 10

Fan Cooled

Serial#: P21G580J Model#: Service Factor: 1.15

Frame: X215T Rated RPM: 3500 Rated Voltage: 230/460

Phase: 3 Rated Amps: 25/12.5 Cycles: 60

Special design: No



### **AC Electrical Inspection**

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing 1.714000 1.677200 1.695400 2.2

### **Test Run Inspection**

Date

Yes I have merged this motor and verified that all electrical tests are complete!

**Power Supply** 

Phase A Phase B Phase C

No Load Voltage 3.984 4.359 4.214

No Load Current 460 460 460

**Temperatures: (Degrees Fahrenheit)** 

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



# **Test Run Inspection (Continued)**

Ambient Temp:				
TIME	DE	Degree Change	ODE	Degree Change
START:				
5 MIN:				
10 MIN:				
15 MIN:				
20 MIN:				
25 MIN:				
30 MIN:				
35 MIN:				
40 MIN:				
45 MIN:				
50 MIN:				
55 MIN:				
60 MIN:				



## **Test Run Inspection (Continued)**

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE 0.113 0.113 0.073

ODE 0.077 0.090 0.083

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

### **Additional photos**







Yes, the shaft has been isolated for delivery.

Service Tech name: Kelly Felts

Service Tech signature:

Kelly Felts