

#### **Job Information**

Job #: 141806 Date: March 3, 2020

Priority: — Authorized OT: No Authorized by:

**Customer Information** 

Name: South Treatment Plant Motor#:

**Name Plate Information** 

Manufacturer: Reliance Enclosure: Totally Enclosed Horsepower/kW: .5

Fan Cooled

Serial#: 141806/1 Model#: 500947-LW Service Factor:

Frame: K48 Rated RPM: 1724 Rated Voltage: 440

Phase: 3 Rated Amps: 1 Cycles: 60

Special design: Yes

Date

November 1, 2019



### **AC Electrical Inspection**

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

**Winding Resistance Incoming** 

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing 33.570 33.600 33.600 0.1

### **Test Run Inspection**

— I have merged this motor and verified that all electrical tests are complete!

**Power Supply** 

	Phase A	Phase B	Phase C
No Load Voltage	0.7	0.7	0.8
No Load Current	440	440	440

**Temperatures: (Degrees Fahrenheit)** 

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



# **Test Run Inspection (Continued)**

Ambient Temp:				
TIME	DE	Degree Change	ODE	Degree Change
START:				
5 MIN:				
10 MIN:				
15 MIN:				
20 MIN:				
25 MIN:				
30 MIN:				
35 MIN:				
40 MIN:				
45 MIN:				
50 MIN:				
55 MIN:				
60 MIN:				



## **Test Run Inspection (Continued)**

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE

ODE

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

### **Additional photos**







Yes, the shaft has been isolated for delivery.

Service Tech name: Kelly Felts

Service Tech signature:

Kelly Felts