

Job Information

Job #: 142844 Date: July 29, 2020

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: Ktg Motor#:

Name Plate Information

Manufacturer: Star electric Enclosure: Open Drop Proof Horsepower/kW: 1.1

(ODP)

Serial#: Service Factor:

Frame: Rated RPM: 600 Rated Voltage: 440

Phase: 3 Rated Amps: 2.5 Cycles: 60

Special design: No



AC Electrical Inspection

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing 18.161 18.185 18.195 0.2

Test Run Inspection

Date July 29, 2020

Yes I have merged this motor and verified that all electrical tests are complete!

Power Supply

 Phase A
 Phase B
 Phase C

 No Load Voltage
 438.6
 442.2
 440.3

 No Load Current
 1.38
 1.95
 1.66

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.

76

3



76

Test Run Inspection (Continued)

Ambient Temp: 73

TIME	DE	Degree Change	ODE	Degree Change
START:	73	0	73	0
5 MIN:	75	2	75	2
10 MIN:	76	3	76	3

3

20 MIN:

15 MIN:

25 MIN:

30 MIN:

35 MIN:

40 MIN:

45 MIN:

50 MIN:

55 MIN:

60 MIN:



Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal	VDE	Axial

DE 0.051 0.020 0.030

ODE 0.046 0.022 0.023

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos







Yes, the shaft has been isolated for delivery.

Service Tech name: Shawn

Service Tech signature:

Hym,