

Job Information

Job #: 94157 Date: May 9, 2018

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: Entergy White Bluff Motor#: B 2B

Name Plate Information

Manufacturer: GE Enclosure: Open Drop Proof Horsepower/kW: 30Hp

(ODP)

Serial#: XSP1442MQ02B Model#: 5KE284DSP103 Service Factor: 1.15

Frame: 284TC Rated RPM: 3550 Rated Voltage: 460

Phase: 3 Rated Amps: 35.7 Cycles: 60

Special design: No

Date

May 9, 2018



AC Electrical Inspection

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing 0.384 0.384 0.384 0.1

Test Run Inspection

— I have merged this motor and verified that all electrical tests are complete!

Power Supply

	Phase A	Phase B	Phase C
No Load Voltage	460	458	458
No Load Current	9.3	9.3	8.8

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



Test Run Inspection (Continued)

Ambient Temp:				
TIME	DE	Degree Change	ODE	Degree Change
START:				
5 MIN:				
10 MIN:				
15 MIN:				
20 MIN:				
25 MIN:				
30 MIN:				
35 MIN:				
40 MIN:				
45 MIN:				
50 MIN:				
55 MIN:				
60 MIN:				



Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE 0.02

ODE 0.01

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos







Yes, the shaft has been isolated for delivery.

Service Tech name: Lynn McDonald

Service Tech signature:

Lynn NDanel