

### **Job Information**

Job #: 94763 Date: October 22,

2018

Priority: — Authorized OT: No Authorized by:

**Customer Information** 

Name: Flakeboard Motor#:

**Name Plate Information** 

Manufacturer: Reliance Enclosure: Totally Enclosed Horsepower/kW: 60

Fan Cooled

Serial#: 43MN360319G00XX Model#: P36G0319K Service Factor: 1.15

Frame: 364T Rated RPM: 1775 Rated Voltage: 230/460

Phase: 3 Rated Amps: 144/72.4 Cycles: 60

Special design: No



# **AC Electrical Inspection**

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

**Winding Resistance Incoming** 

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing 0.151 0.151 0.152 0.5

## **Test Run Inspection**

Date October 22, 2018

— I have merged this motor and verified that all electrical tests are complete!

#### **Power Supply**

,	Phase A	Phase B	Phase C
No Load Voltage	460	459	459
No Load Current	22.9	22.9	23.0

**Temperatures: (Degrees Fahrenheit)** 

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



# **Test Run Inspection (Continued)**

Ambient Temp:				
TIME	DE	Degree Change	ODE	Degree Change
START:				
5 MIN:				
10 MIN:				
15 MIN:				
20 MIN:				
25 MIN:				
30 MIN:				
35 MIN:				
40 MIN:				
45 MIN:				
50 MIN:				
55 MIN:				
60 MIN:				



## **Test Run Inspection (Continued)**

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE

ODE

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

## **Additional photos**







Yes, the shaft has been isolated for delivery.

Service Tech name: Lynn McDonald

Service Tech signature:

Lym McDonald