

Job Information

Job #: 95167 Date: April 17, 2019

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: Flakeboard Motor#:

Name Plate Information

Manufacturer: Reliance Enclosure: Open Drop Proof Horsepower/kW: 200

(ODP)

Serial#: Type:P Model#: ID: Service Factor: 1:15

3MAF25496-62-

Frame: 445T Rated RPM: 1780 Rated Voltage: 460

Phase: 3 Rated Amps: 229 Cycles: 60

Special design: No



AC Electrical Inspection

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing 13.2 13.3 13.2 0.1

Test Run Inspection

Date April 17, 2019

Yes I have merged this motor and verified that all electrical tests are complete!

Power Supply

 Phase A
 Phase B
 Phase C

 No Load Voltage
 460
 457
 458

 No Load Current
 67.8
 67.4
 66.7

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



Test Run Inspection (Continued)

Ambient Temp:				
TIME	DE	Degree Change	ODE	Degree Change
START:				
5 MIN:				
10 MIN:				
15 MIN:				
20 MIN:				
25 MIN:				
30 MIN:				
35 MIN:				
40 MIN:				
45 MIN:				
50 MIN:				
55 MIN:				
60 MIN:				



Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE 0.015 0.035 0.075

ODE 0.022 0.050 0.065

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos







Yes, the shaft has been isolated for delivery.

Service Tech name: Terrence Holland

Service Tech signature:

- Holland