

Job Information

Job #: 97161 Date: September 8,

2020

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: ConAgra Motor#:

Name Plate Information

Manufacturer: Ram Enclosure: Open Drop Proof Horsepower/kW: 900

(ODP)

Serial#: LNY3KBXX258Z004 Model#: W200040012 Service Factor: 1.15

001

Frame: 5810 Rated RPM: 3585 Rated Voltage: 4160

Phase: 3 Rated Amps: 107 Cycles: 60

Special design: No



AC Electrical Inspection

Megs at reassembly: Good Surge at reassembly: Good Hi-pot reassembly: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Outgoing

Test Run Inspection

Date September 8, 2020

Yes I have merged this motor and verified that all electrical tests are complete!

Power Supply

	Phase A	Phase B	Phase C
No Load Voltage	4151	4156	4168
No Load Current	28.2	26.7	27.3

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.



Test Run Inspection (Continued)

Ambient Temp:

TIME	DE	Degree Change	ODE	Degree Change
START:	92.6		92.6	
5 MIN:	95.6		95.8	
10 MIN:	98.2		101.2	
15 MIN:	100.6		102.4	
20 MIN:				
25 MIN:				
30 MIN:				
35 MIN:				
40 MIN:				
45 MIN:	101.8		102.6	
50 MIN:				
55 MIN:				
60 MIN:	102.8		104.	

7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301

WEST TENNESSEE



Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

	Horizontal	VDE	Axial
DE	0.02	0.04	0.008
ODE	04	0.03	0.009

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos







Yes, the shaft has been isolated for delivery.

Service Tech name: **Robert Wiley**

Service Tech signature: