

#### **Job Information**

Job #: 94345 Date:

Priority: — Authorized OT: No Authorized by:

## **Customer Information**

Name: Skippy Reason:

Contact: Motor#: PO#:

Application: – Special notes:

#### **Name Plate Information**

Manufacturer: Louis Allis Enclosure: Totally Enclosed Enclosure Type image

Fan Cooled

Serial#: 44742F Model#:

Service Factor: 1.15 Frame: 326TCZ

Horsepower/kW: 40 Rated RPM: 3535

Rated Amps: 100/46 Rated Voltage: 230/460

Phase: 3 Cycles: 60

No

Nameplate DE ODE F1 F2 Top



Special design:











Fax 901-873-5301



# **Mechanical Inspection**

Inspect bolt holes and fasteners. Validate correct fasteners.

Does the shaft turn freely?: No Contaminant(s): None

Shaft rotation: — Contaminant(s) Amt: None

Shaft grounding device

present?:

Type of grounding device:

Shaft runout(TIR-Inbound):

Bearings DE: Fell Apart Bearings DE make: Koyo

Insulated: No Bearing DE Size: 6313

Bearings ODE: Worn Bearings ODE make: Koyo

Bearing Type: Ball Bearing ODE Size: 6210ZZC3

Bearings Retainer: Yes Thermal Protection: No

Retainer condition: — Thermal Protection Type: —

Bearing Type Image



Bearing Make Image



Bearing Retainer Image



Thermal Protection





## **Mechanical Inspection (Continued)**

Lubrication Type: Grease Thermal Protection device DE: -

Lubrication brand inbound: Mobile Polyrex EM Thermal Protection device ODE: —

Lubrication brand outbound: Mobile Polyrex EM

Grease Amt DE: 1/4 Grease Cond. DE: New

Grease Amt ODE: 1/4 Grease Cond. ODE: New

Seals DE type: N/A

Seals DE size:

Seals DE (inbound) condition:

Seals ODE type: N/A

Seals ODE size:

Seals ODE (inbound) condition

:

Shaft damage cause: None



# **Mechanical Inspection (Continued)**

Brg. Image:



Water jacket: Ok Fan: Ok Frame cond.: Good



Horizontal/Foot mount Endbell type: Single piece

Missing parts? Endbell Image:

☐ J-Box cover ☐ O-rings ☐ J-Box

☐ HH cover ☐ Glands ☑ None

Other missing parts

Motor Mount Position:





## **Mechanical Inspection (Continued)**

#### Air Gap Meaurements (N/A on Single Piece Endbell)

Does Air Gap Meet Customer or EASA spec(<10% variation)?

DE @ 0 ODE @ 0 -

DE @ 90 ODE @ 90

DE @ 180 ODE @ 180

DE @ 270 ODE @ 270

## **AC Electrical Inspection**

Number of leads: 9 Terminal Markings:

Length of leads: 12" REF: NEMA Stds. MG 1-2009, Rev. 1-2010, 2.41-Terminal

Markings Identified By Color:

Size of leads: #8 1-Blue 5-Black P1-No color assigned

2-White 6-No color assigned P2-Brown

3-Orange 7-No color assigned

Lead condition: Good 4-Yellow 8-Red

Connections As Received: Lug type:

Lug Condition: — Terminal Lugs

Lug size:

Lug Attachment: —

Fax 901-873-5301

Failure Image:



# **AC Electrical Inspection (Continued)**

Rotor Type: Cast Aluminum

Rotor Condition: Ok

Num rotor bars:

Num broken bars:

Rotor



#### **Rotor Test Results**

Stator Image:

Visual: Pass Growler: Pass Single phase: Pass

Stator type: Other If other, stator type:

Stator condition: Questionable If other, stator condition:

Failure location: Other If other, stator failure:







## **AC Electrical Inspection (Continued)**

Winding color: Shiny black Winding image Winding Thermal Protection: No

Winding condition: Solid

Winding Thermal \_\_\_\_ Protection DE:

Winding Thermal Protection ODE:

Stator test results: Rewind

Megs incoming: Good Surge incoming: Good Hi-pot incoming: Good

**Winding Resistance Incoming** 

Phases A to B Phases B to C Phases C to A Resistive imbalance

Incoming 0.166 0.166 0.166 0.1

Leads/jumpers: Ok Lead jumper Image:

If other, leads/jumpers:



set Diley



## Conclusion

#### **Component Failure**

#### **Cause of Failure**

Drive end bearing came apart due to lack of grease

#### **Comments**

Stator rewind new bearings #1&#2 bearing housing fits bad needs new shaft and break pads

Service Tech name: Robert Wiley

Service Tech signature: