

#### **Job Information**

Job #: 94530 Date: September 5,

2018

Priority: — Authorized OT: No Authorized by:

**Customer Information** 

Name: DeWafelbakkers Reason:

Contact: Motor#: PO#:

Application: – Special notes:

**Name Plate Information** 

Manufacturer: Taco Enclosure: Totally Enclosed Enclosure Type image

Fan Cooled

Serial#: RBH6164039115 Model#: NPO154

Service Factor: 1.15 Frame: 254T

Horsepower/kW: 15 Rated RPM: 1765

Rated Amps: 34.6/17.3 Rated Voltage: 230/460

Phase: 3 Cycles: 60

Special design: No

Nameplate DE ODE F1 F2 Top













Fax 901-873-5301



### **Mechanical Inspection**

Inspect bolt holes and fasteners. Validate correct fasteners.

Does the shaft turn freely?: Yes Contaminant(s): Water

Shaft rotation: Bi-directional Contaminant(s) Amt: Other

Shaft grounding device

present?: Contaminant Image:

Type of grounding device:

Shaft runout(TIR-Inbound):

Bearings DE: Worn Bearings DE make: SKF

Insulated: No Bearing DE Size: 6309 ZZ

Bearings ODE: Worn Bearings ODE make: SKF

Bearing Type: Ball Bearing ODE Size: 630 ZZ

Bearings Retainer: No Thermal Protection: No

Retainer condition: — Thermal Protection Type: —

Bearing Type Image



Bearing Make Image



Bearing Retainer Image

Not Available Not Available

Thermal Protection



### **Mechanical Inspection (Continued)**

Lubrication Type: Grease Thermal Protection device DE: -

Lubrication brand inbound: Mobile Polyrex EM Thermal Protection device ODE: —

Lubrication brand outbound: Mobile Polyrex EM

Grease Amt DE: 1/4 Grease Cond. DE: Other

Grease Amt ODE: 1/4 Grease Cond. ODE: Other

Seals DE type: Slinger Seals Image:

Seals DE size:

Not
Available

Seals DE (inbound) condition:

Seals Image 2:

Not Seals ODE size: Available

Seals ODE (inbound) condition

Seals ODE type:

:

N/A

Shaft damage cause: None Shaft Image:



# **Mechanical Inspection (Continued)**

Brg. Image:



Bushings/sleeves image:



Water jacket:

N/A

Fan: Ok

Frame cond.:

Good

Not Available



Endbell Image:

Motor Mount Position:

Horizontal/Foot mount

Endbell type:

Single piece

Missing parts?

☐ J-Box cover

O-rings

☐ J-Box

☐ HH cover

Glands

☐ None



Other missing parts

Coupling set screw



### **Mechanical Inspection (Continued)**

Air Gap Meaurements (N/A on Single Piece Endbell)

Does Air Gap Meet Customer or EASA

spec(<10% variation)?

DE @ 0 ODE @ 0 -

DE @ 90 ODE @ 90

DE @ 180 ODE @ 180

DE @ 270 ODE @ 270

**AC Electrical Inspection** 

Number of leads: 12 Terminal Markings:

Length of leads: 8" REF: NEMA Stds. MG 1-2009, Rev. 1-2010, 2.41-Terminal

Markings Identified By Color:

Size of leads: 1-Blue 5-Black P1-No color assigned

2-White 6-No color assigned P2-Brown

3-Orange 7-No color assigned

Lead condition: Good 4-Yellow 8-Red

Connections As Received: 460 volt Lug type:

Lug Condition: — Terminal Lugs

Lug size:

Not Not

Lug Attachment: — Available Available

Rotor



# **AC Electrical Inspection (Continued)**

Rotor Type: Cast Aluminum

Ok

Num rotor bars:

Num broken bars:

#### **Rotor Test Results**

**Rotor Condition:** 

Visual: Pass Growler: Pass Single phase: Pass

Stator type: Factory If other, stator type:

Stator condition: Ok If other, stator condition:

Failure location: Other If other, stator failure:

Stator Image: Failure Image:

Tandre III

Not Available



## **AC Electrical Inspection (Continued)**

Winding color: Like new Winding image Winding Thermal Protection: No

Winding condition: Solid

Winding Thermal \_\_\_\_ Protection DE:

Winding Thermal Protection ODE:

Stator test results: Salvageable

Not Available

Megs incoming: Good Surge incoming: Good Hi-pot incoming: Good

**Winding Resistance Incoming** 

Phases A to B Phases B to C Phases C to A Resistive imbalance

Incoming 0.575 0.575 0.575 0.1

Leads/jumpers: Ok Lead jumper Image. :

Not Stable Not Available



#### Conclusion

**Component Failure** 

Bearings contaminated by water

**Cause of Failure** 

**Comments** 

Service Tech name: Lynn McDonald

Service Tech signature:

Fax 901-873-5301

Lynn Madonala