

Job Information

Job #: 94386 Date: June 12, 2018

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: Democrat Printing Reason:

Contact: Motor#: PO#:

Application: – Special notes:

Name Plate Information

Manufacturer: Siemens Enclosure: Totally Enclosed Enclosure Type image

Non-Ventilated

Serial#: 1PH7167-2EG330B Model#: DB8

Service Factor: Frame:

Horsepower/kW: 41/44/44 kW Rated RPM: 2000/2300/2650

Rated Amps: 89/85/77 Rated Voltage: 350/398/450

Phase: 3 Cycles: 67/77/89

No

Nameplate DE ODE F1 F2 Top



Special design:







YFV846071301004







present?:

Bearings DE:

Type of grounding device:

Shaft runout(TIR-Inbound):

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Does the shaft turn freely?: Yes Contaminant(s): Dirt

Shaft rotation: — Contaminant(s) Amt: Other

Shaft grounding device No Contaminant Image:

Worn

Insulated: No Bearing DE Size: 6313 2RS

Bearings ODE: Worn Bearings ODE make: Other

Bearing Type: Ball Bearing ODE Size: 6212 2RS

Bearings Retainer: No Thermal Protection: No

Retainer condition: — Thermal Protection Type: —

Bearing Type Image



Bearing Make Image



Bearing Retainer Image

Bearings DE make:

Other



Thermal Protection

Not Available



Mechanical Inspection (Continued)

Lubrication Type: Grease Thermal Protection device DE: N/A

Lubrication brand inbound: Unknown Thermal Protection device ODE: Thermal Overloads

Lubrication brand outbound: Unknown

Grease Amt DE: 1/4 Grease Cond. DE: Other

Grease Amt ODE: 1/4 Grease Cond. ODE: Other

Seals DE type: Other Seals Image:

Seals DE size: 68-90-10

Seals DE (inbound) condition: Fair

Seals ODE type:

Seals ODE size:

Seals Image 2:

Not Available

Seals ODE (inbound) condition

N/A

Shaft damage cause: None Shaft Image:

Fax 901-873-5301



Mechanical Inspection (Continued)

Brg. Image:



Bushings/sleeves image:



Water jacket:

N/A

Fan:

N/A

Frame cond.:

Good

Not Available Not Available



Motor Mount Position:

Horizontal/Flange mount

Endbell type:

Endbell Image:

Single piece

Missing parts?

✓ J-Box cover

O-rings

J-Box

☐ HH cover

Glands

☐ None

Other missing parts





Mechanical Inspection (Continued)

Air Gap Meaurements (N/A on Single Piece Endbell)

Does Air Gap Meet Customer or EASA spec(<10% variation)?

DE @ 0 ODE @ 0

DE @ 90 **ODE @ 90**

DE @ 180 **ODE @ 180**

DE @ 270 **ODE @ 270**

AC Electrical Inspection

Number of leads: 6 Terminal Markings:

REF: NEMA Stds. MG 1-2009, Rev. 1-2010, 2.41-Terminal Length of leads:

Markings Identified By Color:

P1-No color assigned 5-Black 1-Blue Size of leads:

P2-Brown 2-White 6-No color assigned

7-No color assigned 3-Orange

4-Yellow 8-Red Lead condition: Good

Connections As Received: Lug type:

Lug Condition: Good Terminal Lugs

Lug size:

Not Available Lug Attachment: Acceptable

Rotor



AC Electrical Inspection (Continued)

Rotor Type: Cast Aluminum

Ok

Num rotor bars:

Num broken bars:

Rotor Test Results

Rotor Condition:

Visual: Pass Growler: Pass Single phase: Pass

Stator type: Factory If other, stator type:

Stator condition: Ok If other, stator condition:

Failure location: Other If other, stator failure:

Stator Image: Failure Image:

Not Available



AC Electrical Inspection (Continued)

Winding color: Like new Winding image Winding Thermal Protection: Yes

Winding condition: Solid

Winding Thermal Protection DE:

Winding Thermal Good Protection ODE:

Stator test results: Salvageable

Not Available

Megs incoming: Good Surge incoming: Good Hi-pot incoming: Good

Winding Resistance Incoming

Phases A to B Phases B to C Phases C to A Resistive imbalance

Incoming 51.098 51.052 51.132 0.1

Leads/jumpers: Ok Lead jumper Image. :

Not Stable Not Available



Conclusion

Component Failure

Cause of Failure

Comments

Recondition only

Service Tech name: Lynn McDonald

Service Tech signature:

Fax 901-873-5301