**Enclosure Type image** 



#### **Job Information**

Job #: 94408 Date: June 28, 2018

Priority: Authorized OT: No Authorized by:

## **Customer Information**

Name: Horseless Reason:

Contact: Motor#: PO#:

Application: Special notes:

#### **Name Plate Information**

Manufacturer: Demagogue Enclosure: Totally Enclosed

Non-Ventilated

ANR340303-16010 Serial#: 70706323 Model#:

084-02

Service Factor: Frame:

Horsepower/kW: 1.35 Rated RPM: 1660

Rated Amps: 5.5/2.7 Rated Voltage: 230/460

Phase: 3 Cycles: 60

Special design:

No

Nameplate DE ODE F1 F2 Top













Not



# **Mechanical Inspection**

Inspect bolt holes and fasteners. Validate correct fasteners.

Does the shaft turn freely?: Yes Contaminant(s): None

Shaft rotation: — Contaminant(s) Amt: None

Shaft grounding device No Contaminant Image:

present?:

Type of grounding device:

Available

Shaft runout(TIR-Inbound):

Bearings DE: Other Bearings DE make: Other

Insulated: No Bearing DE Size:

Bearings ODE: Other Bearings ODE make: Other

Bearing Type: Ball Bearing ODE Size:

Bearings Retainer: No Thermal Protection: Yes

Retainer condition: — Thermal Protection Type: Thermocouple

Bearing Type Image Bearing Make Image Bearing Retainer Image Thermal Protection

Not Not Not Not Available Available Available

ax 901-873-5301



## **Mechanical Inspection (Continued)**

Lubrication Type: Grease Thermal Protection device DE:

Lubrication brand inbound: Unknown Thermal Protection device ODE:

Lubrication brand outbound: Unknown

> Grease Amt DE: Full Grease Cond. DE: Other

Grease Amt ODE: Full Grease Cond. ODE: Other

Seals DE type: Seals Image: Other

Not Seals DE size: Available

Seals DE (inbound) condition:

Seals ODE (inbound) condition

Shaft damage cause:

Seals Image 2:

Seals ODE type: Not Available

Seals ODE size:

Other

None

Shaft Image:



# **Mechanical Inspection (Continued)**

Brg. Image:

Bushings/sleeves image:

Not Available

Not Available

Water jacket:

N/A

Fan:

N/A

Frame cond.:

Good

Not Available Not Available



Motor Mount Position:

Horizontal/Foot mount

Endbell type:

Endbell Image:

Single piece

Missing parts?

☐ J-Box cover

O-rings

☐ J-Box

☐ HH cover

Glands

■ None

Other missing parts





# **Mechanical Inspection (Continued)**

Air Gap Meaurements (N/A on Single Piece Endbell)

Does Air Gap Meet Customer or EASA spec(<10% variation)?

DE @ 0 ODE @ 0

DE @ 90 **ODE @ 90** 

DE @ 180 **ODE @ 180** 

DE @ 270 **ODE @ 270** 

#### **AC Electrical Inspection**

Number of leads: 9 Terminal Markings:

REF: NEMA Stds. MG 1-2009, Rev. 1-2010, 2.41-Terminal Length of leads:

Markings Identified By Color:

P1-No color assigned 5-Black 1-Blue Size of leads: P2-Brown

2-White 6-No color assigned

7-No color assigned 3-Orange

4-Yellow 8-Red Lead condition: Good

Connections As Received: Lug type:

Lug Condition: Good Terminal Lugs

Lug size:

Lug Attachment: Acceptable



Not Available



# **AC Electrical Inspection (Continued)**

Rotor Type: Cast Aluminum

Rotor

Rotor Condition: Ok

Num rotor bars:

Num broken bars:

Not Available

**Rotor Test Results** 

Visual: Pass

Growler:

**Pass** 

Single phase:

Pass

Stator type:

Factory

If other, stator type:

Stator condition:

Ok

If other, stator condition:

Failure location:

Other

If other, stator failure:

Stator Image:

Failure Image:

Not Available

Not Available



# **AC Electrical Inspection (Continued)**

Winding color: Like new Winding image Winding Thermal Protection: Yes

Winding condition: Solid

Winding Thermal Protection DE: Not Available Available

Winding Thermal Protection ODE:

Stator test results: Salvageable

Megs incoming: Good Surge incoming: Good Hi-pot incoming: Good

**Winding Resistance Incoming** 

Phases A to B Phases B to C Phases C to A Resistive imbalance

Incoming 22.536 22.523 22.521 0.1

Leads/jumpers: Ok Lead jumper Image. :

Not Available



#### Conclusion

**Component Failure** 

**Cause of Failure** 

#### **Comments**

Motor tests good, disassembled motor and lubed the bearings reassembled and adjusted brake

Lynnald

Service Tech name: Lynn McDonald

Service Tech signature:

Fax 901-873-5301