



MILLINGTON, TN

LITTLE ROCK, AR

## Job Information

Job #: 136674

Date: February 16, 2018

Priority: —

Authorized OT: Yes

Authorized by:

## Customer Information

Name: Friedman ind

Motor#:

## Name Plate Information

Manufacturer: Westinghouse      Enclosure : Open Drop Proof      Horsepower/kW: 450  
(ODP)

Serial#: 1s-70      Model#: 70f97789      Service Factor:

Frame: Fb848asy      Rated RPM: 247/935      Rated Voltage: 120/240

Phase:      Rated Amps:      Cycles:

Special design: No

## Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good

Bearings Retainer: Yes

Type of grounding device:

Bearing DE Size: 6324

Shaft runout(TIR-Inbound): .001

Bearing ODE Size: 6324

Retainer condition: —

**WEST TENNESSEE**  
7030 Ryburn Drive  
Millington, TN 38053  
Phone 901-873-5300  
Fax 901-873-5301

**CENTRAL ARKANSAS**  
6812 Lindsey Rd.  
Little Rock, AR 72206  
Phone 501-375-9178  
Fax 501-375-4254

## Mechanical Inspection (Continued)

Seals DE condition :	Worn	Brg. Seats DE:	Good
Seals DE type:	Slinger	If DE undersized, amt.:	.000
Seals DE size:		Brg. Seats ODE:	Good
Seals DE (inbound) condition :		If ODE undersized, amt.:	.000
Seals ODE condition :	Worn	Shaft damage:	OK
Seals ODE type:	Slinger	Bushings/sleeves DE:	Ok
Seals ODE size:		Bushings/sleeves ODE:	Ok
Seals ODE (inbound) condition :			
Endbell fits/damage:	Good	Foot/Flange condition:	Ok
Endbell DE size:	10.2365	Foot flatness:	Pass
Endbell DE insulated?:	No	Does Air Gap Meet Customer or EASA spec(<10% variation)?	
Endbell ODE size:	10.2373		
Endbell ODE insulated?:	No	Yes	

## Conclusion

Service Tech name: Billy mays

Service Tech signature:

