

### **Job Information**

Job #: 137047 Date: June 14, 2018

Priority: — Authorized OT: No Authorized by:

## **Customer Information**

Name: XYLEM DEWATERING SOLUTIONS Motor#:

### **Name Plate Information**

Manufacturer: FLYGT Enclosure: Open Drop Proof Horsepower/kW: 8.9

(ODP)

Serial#: — Model#: 2640.181-1720154 Service Factor:

Frame: Rated RPM: 3495 Rated Voltage: 460

Phase: 3 Rated Amps: 11 Cycles: 60

Special design: No

# **Mechanical Inspection**

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good Bearings Retainer: Yes

Type of grounding device: Bearing DE Size: 3304

Shaft runout(TIR-Inbound): .001 Bearing ODE Size: 6304

Retainer condition: Good



## **Mechanical Inspection (Continued)**

Seals DE condition: Worn Brg. Seats DE: Good

Seals DE type: Slinger If DE undersized, amt.: .000

Seals DE size: Brg. Seats ODE: Good

Seals DE (inbound) condition: If ODE undersized, amt.: .000

Seals ODE condition: Shaft damage: OK Worn

Seals ODE type: Slinger

Bushings/sleeves DE: Ok Seals ODE size:

Bushings/sleeves ODE: Ok Seals ODE (inbound) condition:

> Endbell fits/damage: Good Foot/Flange condition: Ok

Endbell DE size: 2.0466 Foot flatness: **Pass** 

Endbell DE insulated?: No

> Does Air Gap Meet Customer or EASA spec(<10% Endbell ODE size:

variation)?

Endbell ODE insulated?:

#### Conclusion

Service Tech name:

Service Tech signature: