

Job Information

Job #: 137915 Date: August 20, 2018

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: PLASKOLITE INC Motor#:

Name Plate Information

Manufacturer: MARATHON Enclosure: Weather Protected Horsepower/kW: 3/4

II (WPII)

Serial#: N/A Model#: WE145TGS7101B Service Factor: :1

B-W

Frame: 145T Rated RPM: 855 Rated Voltage: 230/460

Phase: 3 Rated Amps: 4/2 Cycles: 60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good Bearings Retainer: Yes

Type of grounding device: Bearing DE Size: 6203

Shaft runout(TIR-Inbound): .001 Bearing ODE Size: 6205

Retainer condition: Good



Mechanical Inspection (Continued)

Seals DE condition: Worn Brg. Seats DE: Good

Seals DE type: Slinger If DE undersized, amt.: .000

Seals DE size: Brg. Seats ODE: Good

Seals DE (inbound) condition: If ODE undersized, amt.: .000

Seals ODE condition: Shaft damage: OK Worn

Seals ODE type: Slinger

Bushings/sleeves DE: Ok Seals ODE size:

Bushings/sleeves ODE: Ok Seals ODE (inbound) condition:

> Endbell fits/damage: Good Foot/Flange condition: Ok

Endbell DE size: 2.0472 Foot flatness: **Pass**

Endbell DE insulated?: No

> Does Air Gap Meet Customer or EASA spec(<10% Endbell ODE size:

variation)? 1.582

Endbell ODE insulated?: No Yes

Conclusion

Service Tech name: **BILLY MAYS**

Service Tech signature: