

Job Information

Job #: 140785 Date: October 29,

2019

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: USG Motor#:

Name Plate Information

Manufacturer: Enclosure: Open Drop Proof Horsepower/kW:

(ODP)

Serial#: Service Factor:

Frame: Rated RPM: Rated Voltage:

Phase: Rated Amps: Cycles:

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good Bearings Retainer: Yes

Type of grounding device: Bearing DE Size: 6314

Shaft runout(TIR-Inbound): .0000 Bearing ODE Size: 6314

Retainer condition: Good



Mechanical Inspection (Continued)

Seals DE condition: Worn Brg. Seats DE: Good

Seals DE type: Slinger If DE undersized, amt.: .000

Seals DE size: Brg. Seats ODE: Good

Seals DE (inbound) condition: If ODE undersized, amt.: .000

Seals ODE condition: Worn Shaft damage: OK

Seals ODE type: Slinger

Bushings/sleeves DE: Ok Seals ODE size:

Seals ODE (inbound) condition : Bushings/sleeves ODE: Ok

Endbell fits/damage: Good Foot/Flange condition: Ok

Endbell DE size: 5.9065 Foot flatness: Pass

Endbell DE insulated?: No

Endbell ODE insulated?:

Does Air Gap Meet Customer or EASA spec(<10%

Endbell ODE size: 5.9065 variation)?

No

Conclusion

Service Tech name: Billy mays

Service Tech signature: