

Job Information

Job #:	140924	Date

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: Kroger Motor#:

Name Plate Information

Manufacturer: RAM Enclosure: Open Drop Proof Horsepower/kW: 250

(ODP)

Serial#: 700765-01-UZ-04 Model#: Service Factor: 1.15

Frame: 445TS Rated RPM: 3565 Rated Voltage: 460

Phase: 3 Rated Amps: Cycles: 60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: — Bearings Retainer: Yes

Type of grounding device: Bearing DE Size:

Shaft runout(TIR-Inbound): Bearing ODE Size:

Retainer condition: —



Mechanical Inspection (Continued)

Seals DE condition: Worn Brg. Seats DE: Undersized

Seals DE type: Slinger If DE undersized, amt.: .0002

Seals DE size: Brg. Seats ODE: Good

Seals DE (inbound) condition: If ODE undersized, amt.:

Seals ODE condition: Shaft damage: OK Worn

Seals ODE type: Slinger

Bushings/sleeves DE: Ok Seals ODE size:

Bushings/sleeves ODE: Ok Seals ODE (inbound) condition:

> Endbell fits/damage: Bad Foot/Flange condition: Ok

Endbell DE size: 5.5145 Foot flatness: **Pass**

Endbell DE insulated?: No

> Does Air Gap Meet Customer or EASA spec(<10% Endbell ODE size: 5.5125

variation)?

Endbell ODE insulated?: No Yes

Conclusion

Service Tech name: Jeremy Yarbrough

Service Tech signature: