

## **Job Information**

Job #: 141127 Date: November 12,

2019

Priority: — Authorized OT: No Authorized by:

**Customer Information** 

Name: Process and Power Motor#:

**Name Plate Information** 

Manufacturer: Reliance Enclosure: Open Drop Proof Horsepower/kW: 300

(ODP)

Serial#: 01MIN87052 Model#: Service Factor: 1.15

Frame: 449TDZ Rated RPM: 1785 Rated Voltage: 460

Phase: 3 Rated Amps: 336 Cycles: 60

Special design: No

**Mechanical Inspection** 

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good Bearings Retainer: Yes

Type of grounding device: N/A Bearing DE Size: 222E

Shaft runout(TIR-Inbound): .0001 Bearing ODE Size: 6318

Retainer condition: Good



## **Mechanical Inspection (Continued)**

Seals DE condition: None Brg. Seats DE: Good

Seals DE type: Slinger If DE undersized, amt.:

Seals DE size: Brg. Seats ODE: Good

Seals DE (inbound) condition: If ODE undersized, amt.:

Seals ODE condition: None Shaft damage: OK

Seals ODE type: Slinger

Bushings/sleeves DE: Ok Seals ODE size:

Seals ODE (inbound) condition :

Bushings/sleeves ODE: Ok

Endbell fits/damage: Good Foot/Flange condition: Ok

Endbell DE size: 7.8750 Foot flatness: Pass

Endbell DE insulated?: No

Endbell ODE size:

Does Air Gap Meet Customer or EASA spec(<10%

variation)?

Endbell ODE insulated?: No Yes

7.4810

## Conclusion

Service Tech name: Jeremy Yarbrough

Service Tech signature:

& Darling