

## **Job Information**

Job #: 38075 Date: October 3, 2018

Priority: — Authorized OT: No Authorized by:

## **Customer Information**

Name: Landmark environmental systems Motor#:

### **Name Plate Information**

Manufacturer: Toshiba Enclosure: Totally Enclosed Horsepower/kW: 75

Fan Cooled

Serial#: 03010061 Model#: B0752flg3umh02 Service Factor: N/a

Frame: 365ts Rated RPM: 3545 Rated Voltage: 230/460

Phase: 3 Rated Amps: 174/87 Cycles: 60

Special design: No

# **Mechanical Inspection**

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good Bearings Retainer: Yes

Type of grounding device: Bearing DE Size: 6312

Shaft runout(TIR-Inbound): .001 Bearing ODE Size: 6312

Retainer condition: Good



## **Mechanical Inspection (Continued)**

Seals DE condition: Worn Brg. Seats DE: Good

Seals DE type: Slinger If DE undersized, amt.: 2.3628

Seals DE size: Brg. Seats ODE: Good

Seals DE (inbound) condition: If ODE undersized, amt.: 2.3628

Seals ODE condition: Shaft damage: OK Worn

Seals ODE type: Slinger

Bushings/sleeves DE: Ok Seals ODE size:

Bushings/sleeves ODE: Ok Seals ODE (inbound) condition:

> Endbell fits/damage: Good Foot/Flange condition: Ok

Endbell DE size: 5.1185 Foot flatness: **Pass** 

Endbell DE insulated?: No

> Does Air Gap Meet Customer or EASA spec(<10% Endbell ODE size: 5.1182

variation)?

Endbell ODE insulated?: No Yes

#### Conclusion

Service Tech name: Billy mays

Service Tech signature: