

### **Job Information**

Job #:	94188				Date:
Priority:	_	Authorized OT:	No	Authorized by:	

# **Customer Information**

Name:	AFT	Motor#:

# **Name Plate Information**

BARTEC VARNOST	Enclosure :	Open Drop Proof (ODP)	Horsepower/kW:	26 KW
	Model#:	3KTC180M-2	Service Factor:	
180M	Rated RPM:	3525	Rated Voltage:	278/480
3	Rated Amps:	71/41	Cycles:	60
	180M	Model#: 180M Rated RPM:	(ODP) Model#: 3KTC180M-2 180M Rated RPM: 3525	(ODP) Model#: 3KTC180M-2 Service Factor: 180M Rated RPM: 3525 Rated Voltage:

Special design: No

## **Mechanical Inspection**

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition:	Good	Bearings Retainer:	Yes
Type of grounding device:	Aegis Ring	Bearing DE Size:	6310 ZZ C3
Shaft runout(TIR-Inbound):		Bearing ODE Size:	6310 ZZ C3

Retainer condition:

WEST TENNESSEE 7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301 CENTRAL ARKANSAS 6812 Lindsey Rd. Little Rock, AR 72206 Phone 501-375-9178 Fax 501-375-4254



### **Mechanical Inspection (Continued)**

Seals DE condition :	Worn	Brg. Seats DE:	Good
Seals DE type:	Other	If DE undersized, amt.:	
Seals DE size:		Brg. Seats ODE:	Good
Seals DE (inbound) condition :		If ODE undersized, amt.:	
Seals ODE condition :	Worn	Shaft damage:	ОК
Seals ODE type:	Labyrinth		
Seals ODE size:		Bushings/sleeves DE:	Ok
Seals ODE (inbound) condition :		Bushings/sleeves ODE:	Ok
Endbell fits/damage:	Good	Foot/Flange condition:	Ok
Endbell DE size:	4.3315	Foot flatness:	Pass
Endbell DE insulated?:	No	Doop Air Con Most Cu	$t_{\rm cm}$ or EASA approximation
Endbell ODE size:	4.3313	variation)?	stomer or EASA spec(<10%
Endbell ODE insulated?:	No	_	

### Conclusion

Service Tech name:

Robert Wiley

Service Tech signature:

Robert Willerg

WEST TENNESSEE 7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301 CENTRAL ARKANSAS 6812 Lindsey Rd. Little Rock, AR 72206 Phone 501-375-9178 Fax 501-375-4254