

## **Job Information**

Job #:	94196	Date
		σαιο

Priority: — Authorized OT: No Authorized by:

## **Customer Information**

Name: L'Oréal Motor#:

## **Name Plate Information**

Manufacturer: BARTEC VARNOST Enclosure: Totally Enclosed Horsepower/kW: 6.6 KW

Fan Cooled

Serial#: Service Factor:

Frame: Rated RPM: Rated Voltage:

Phase: Rated Amps: Cycles:

Special design: No

# **Mechanical Inspection**

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good Bearings Retainer: Yes

Type of grounding device: Bearing DE Size: 6208 ZZC3

Shaft runout(TIR-Inbound): Bearing ODE Size: 6208 ZZC3

Retainer condition: —



## **Mechanical Inspection (Continued)**

Brg. Seats DE: Seals DE condition: Worn Good

Seals DE type: Other If DE undersized, amt.:

Seals DE size: 40 80 10 Brg. Seats ODE: Good

Seals DE (inbound) condition: Good If ODE undersized, amt.:

Seals ODE condition: Worn Shaft damage: OK

Seals ODE type: Other

Bushings/sleeves DE: Ok Seals ODE size: 40 80 10

Bushings/sleeves ODE: Ok Seals ODE (inbound) condition: Good

> Endbell fits/damage: Good Foot/Flange condition: Ok

Endbell DE size: 3.1502 Foot flatness: **Pass** 

Endbell DE insulated?: No

> Does Air Gap Meet Customer or EASA spec(<10% Endbell ODE size: 3.1501

variation)?

obst Wilcox

Endbell ODE insulated?: No

#### Conclusion

Service Tech name: **Robert Wiley** 

Service Tech signature:

WEST TENNESSEE CENTRAL ARKANSAS 6812 Lindsey Rd. 7030 Ryburn Drive Little Rock, AR 72206

Phone 501-375-9178

Fax 501-375-4254

dillington, TN 38053 one 901-873-5300 x 901-873-5301