

Job Information

Job #: 94225 Date: May 11, 2018

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: Delta plastics Motor#:

Name Plate Information

Manufacturer: Baldor Enclosure: Open Drop Proof Horsepower/kW: 150

(ODP)

Serial#: B889014 Model#: B9126122-020002 Service Factor: 1.00

JG

Frame: L5034A Rated RPM: 1750/2000 Rated Voltage: 460

Phase: 3 Rated Amps: 180/181 Cycles: 60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good Bearings Retainer: Yes

Type of grounding device: N/a Bearing DE Size: Nu215ec

Shaft runout(TIR-Inbound): .001 Bearing ODE Size: 6211/C3

Retainer condition: Good



Mechanical Inspection (Continued)

Seals DE condition: None Brg. Seats DE: Good

Seals DE type: N/A If DE undersized, amt.: 2.9465

Seals DE size: Brg. Seats ODE: Good

Seals DE (inbound) condition: If ODE undersized, amt.:

Seals ODE condition: Shaft damage: OK None

Seals ODE type: N/A

Bushings/sleeves DE: Ok Seals ODE size:

Bushings/sleeves ODE: Ok Seals ODE (inbound) condition:

> Endbell fits/damage: Good Foot/Flange condition: Ok

Endbell DE size: 5.1190 Foot flatness: **Pass**

Endbell DE insulated?: No

Endbell ODE size:

Does Air Gap Meet Customer or EASA spec(<10%

variation)?

Endbell ODE insulated?: No

3.9377

Conclusion

Service Tech name: Terrence Holland

Service Tech signature:

WEST TENNESSEE CENTRAL ARKANSAS 6812 Lindsey Rd. Little Rock, AR 72206 Phone 501-375-9178 Fax 501-375-4254