

Job Information

Job #: 94291 Date: May 15, 2018

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: ConAgra Motor#:

Name Plate Information

Manufacturer: Ram Industries Enclosure: Open Drop Proof Horsepower/kW: 437

(ODP)

Serial#: W20002010081-BL Model#: N3KBXX244PVFH Service Factor:

WZ

Frame: 449TDZ Rated RPM: 3570 Rated Voltage: 460

Phase: 3 Rated Amps: 482 Cycles: 60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good Bearings Retainer: Yes

Type of grounding device: Bearing DE Size: 6313

Shaft runout(TIR-Inbound): <.001 Bearing ODE Size: 6313

Retainer condition: —



Mechanical Inspection (Continued)

Seals DE condition: None Brg. Seats DE: Good

Seals DE type: N/A If DE undersized, amt.:

Seals DE size: Brg. Seats ODE: Good

Seals DE (inbound) condition: If ODE undersized, amt.:

Seals ODE condition: None Shaft damage: OK

Seals ODE type: N/A

Bushings/sleeves DE: Ok Seals ODE size:

Seals ODE (inbound) condition : Bushings/sleeves ODE: Ok

Endbell fits/damage: Bad Foot/Flange condition: Ok

Endbell DE size: 5.5128 Good Foot flatness: Pass

Endbell DE insulated?: No

Endbell ODE size:

Does Air Gap Meet Customer or EASA spec(<10%

5.5147 Bad variation)?

Endbell ODE insulated?: No –

Conclusion

Service Tech name: Lynn McDonald

Service Tech signature:

7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301 CENTRAL ARKANSAS 6812 Lindsey Rd. Little Rock, AR 72206 Phone 501-375-9178 fax 501-375-4254