



MILLINGTON, TN

LITTLE ROCK, AR

Job Information

Job #: 94345

Date: June 1, 2018

Priority: —

Authorized OT: No

Authorized by:

Customer Information

Name: Skippy

Motor#:

Name Plate Information

Manufacturer: Louis Allis

Enclosure : Totally Enclosed
Fan Cooled

Horsepower/kW: 40

Serial#: 44742F

Model#:

Service Factor: 1.15

Frame: 326TCZ

Rated RPM: 3535

Rated Voltage: 230/460

Phase: 3

Rated Amps: 100/46

Cycles: 60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Damaged

Bearings Retainer: Yes

Type of grounding device:

Bearing DE Size: 6313ZZC3

Shaft runout(TIR-Inbound):

Bearing ODE Size: 6210ZZC3

Retainer condition: —

WEST TENNESSEE

7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS

6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254



MILLINGTON, TN

LITTLE ROCK, AR

Mechanical Inspection (Continued)

Seals DE condition : None

Brg. Seats DE: Undersized

Seals DE type: N/A

If DE undersized, amt.:

Seals DE size:

Brg. Seats ODE: Undersized

Seals DE (inbound) condition :

If ODE undersized, amt.:

Seals ODE condition : None

Shaft damage: Replace

Seals ODE type: N/A

Bushings/sleeves DE: Ok

Seals ODE size:

Bushings/sleeves ODE: Ok

Seals ODE (inbound) condition :

Endbell fits/damage: Bad

Foot/Flange condition: Ok

Endbell DE size: 5.5135

Foot flatness: Pass

Endbell DE insulated?: No

Does Air Gap Meet Customer or EASA spec(<10% variation)?

Endbell ODE size: 3.5451

Endbell ODE insulated?: —

—

Conclusion

Service Tech name: Robert Wiley

Service Tech signature: